

1	1.8	76	136.8	20.0	8.10	35.2	Yes	1.68
2	1.8	76	136.8	20.0	8.20	33.3	yes	1.22
3	1.4	76	106.4	20.0	8.20	31.9	yes	1.26
4	1.2	76	91.2	20.0	8.20	31.1	yes	1
5	1.4	76	106.4	20.6	8.20	30.6	yes	3.1
6	1.6	76	121.6	21.1	8.30	31.4	yes	2.5
7	1.6	76	121.6	21.1	8.20	30.3	yes	0.9
8	1.8	76	136.4	20.0	8.00	31.0	yes	2
9	1.8	76	136.8	20.0	8.10	32.1	yes	0.8
10	2.2	76	167.2	21.1	8.20	32.4	yes	2.2
11	2	76	152.0	71.7	8.20	0.4	yes	3
12	1.8	76	136.8	21.1	8.10	29.9	yes	1.2
13	1.8	76	136.8	20.6	8.10	30.9	yes	1.8
14	1.8	76	136.8	21.1	8.10	29.9	yes	2
15	1.8	76	136.8	20.5	8.30	33.5	yes	2.2
16	1.6	76	121.6	22.2	8.20	28.1	yes	2
17	1.6	76	121.6	23.9	8.10	24.2	yes	2
18	1.8	76	136.8	23.3	8.20	26.8	yes	1.8
19	2	76	152.0	22.8	8.40	30.5	yes	2
20	2	76	152.0	22.8	8.40	30.5	yes	2.3
21	2.1	76	159.6	22.8	8.40	30.8	yes	2.3
22	2.1	76	159.6	20.6	8.20	33.2	yes	1.8
23	2.1	76	159.6	21.6	8.20	31.0	yes	1.7
24	2.1	76	159.6	20.0	8.30	35.8	yes	1
25	2.1	76	159.6	21.1	8.30	33.3	yes	0.9
26	2.2	76	167.2	21.1	8.20	32.4	yes	2.2
27	2.2	76	167.2	21.1	8.20	32.4	yes	2.2
28	2.2	76	167.2	21.1	8.20	32.4	yes	1.6
29	2.2	76	167.2	20.0	8.30	36.2	yes	0.7
30	2.2	76	167.2	19.4	8.30	37.7	yes	2.3
31	2.2	76	167.2	18.9	8.30	39.0	yes	1.3

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

2.2

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350