

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Josephine
Conventional or Direct Filtration							Month/Year:	Sept/2023
System Name:	Morrisons Rogue River Lodge			ID#: 41 93508			WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1			0.80					
2			0.80					
3			0.80					
4			0.80					
5			0.80					
6			0.80					
7			0.80					
8			0.80					
9			0.80					
10			0.80					
11			0.80					
12			0.80					
13			0.80					
14			0.80					
15			0.80					
16			0.80					
17			0.80					
18			0.80					
19			0.80					
20			0.80					
21			0.80					
22			0.80					
23			0.80					
24			0.80					
25			0.80					
26			0.80					
27			0.80					
28			0.80					
29			0.80					
30			0.80					
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?			Yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All 4-hour turbidity readings ≤ 1 NTU?			Yes	Yes		Yes		
All turbidity readings < IFE ² triggers			Yes					
Notes:				PRINTED NAME: Trenton Douglas				
				Trenton Douglas			10/10/2023	
				PHONE #: (541)476-3825			CERT #: 4193508	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))								
PAGE 1 of 2								
OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - :		
System Name:	Morrisons Rogue River Lodge	ID#: 41 93508		Month/Year:	Sept/2023	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.4	76	182.4	19.4	8.40	40.0	YES	2
2	2.2	76	167.2	20.0	8.30	36.2	YES	2.2
3	2.2	76	167.2	20.0	8.30	36.2	YES	2.4
4	1.6	76	121.6	20.0	8.40	35.1	YES	2.2
5	1.6	76	121.6	18.3	8.30	37.9	YES	2.2
6	1.8	76	136.8	18.3	8.30	38.7	YES	2.5
7	1.4	76	106.4	18.3	8.30	37.0	YES	2.1
8	1.4	76	106.4	18.3	8.30	37.0	YES	2.8
9	1.2	76	91.2	18.3	8.30	36.2	YES	2.5
10	1.2	76	91.2	18.3	8.20	34.9	YES	3.2
11	1.2	76	91.2	18.3	8.20	34.9	YES	0.7
12	1.4	76	106.4	20.0	8.30	33.1	YES	1.5
13	1.8	76	136.8	18.8	8.40	38.9	YES	2.6
14	2.0	76	152.0	18.3	8.40	41.1	YES	0.8
15	1.8	76	136.8	18.3	8.30	38.7	YES	2
16	2.0	76	152.0	18.3	8.30	39.6	YES	1.5
17	2.0	76	152.0	18.3	8.30	39.6	YES	1.5
18	2.0	76	152.0	18.8	8.30	38.3	YES	2
19	2.0	76	152.0	18.8	8.30	38.3	YES	1.3
20	2.0	76	152.0	18.8	8.30	38.3	YES	0.3
21	2.0	76	152.0	16.6	8.30	44.4	YES	2.4
22	1.8	76	136.8	16.6	8.40	45.0	YES	1.8
23	1.8	76	136.8	16.1	8.40	46.5	YES	2
24	1.8	76	136.8	16.1	8.30	44.8	YES	2.3
25	1.8	76	136.8	16.1	8.30	44.8	YES	0.9
26	2.0	76	152.0	16.6	8.30	44.4	YES	3.2
27	1.8	76	136.8	16.6	8.30	43.4	YES	3.1
28	1.8	76	136.8	16.6	8.30	43.4	YES	2.9
29	1.2	76	91.2	15.5	8.30	43.6	YES	3.2
30	1.8	76	136.8	16.1	8.30	44.8	YES	4
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350