

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration



County: **Josephine**  
 Month/Year: **5/1**

System Name: <b>morrison lodge</b>		ID#: <b>4193508</b>		WTP : <b>TP -</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1			0.51				
2			0.51				
3			0.51				
4			0.51				
5			0.51				
6			0.51				
7			0.51				
8			0.51				
9			0.51				
10			0.51				
11			0.51				
12			0.51				
13			0.51				
14			0.51				
15			0.51				
16			0.51				
17			0.51				
18			0.51				
19			0.51				
20			0.51				
21			0.51				
22			0.51				
23			0.51				
24			0.51				
25			0.51				
26			0.51				
27							
28							
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
All turbidity readings < IFE <sup>2</sup> triggers	<b>Yes</b>		

<b>Notes:</b>	<b>Trenton Douglas</b>	
	<b>Trenton Douglas</b>	<b>6/1/2024</b>
	<b>5414799554</b>	<b>CERT #:</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :
Disinfection <i>Giardia</i>
Log Inactive:

System Name: morrison's lodge	ID#: 41	Month/Year: 1-May	1
-------------------------------	---------	-------------------	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2	60	120.0	15.5	8.00	42.7	YES	1.2
2	2	60	120.0	15.5	8.00	42.7	YES	1.1
3	2	60	120.0	15.5	8.00	42.7	YES	1.2
4								
5								
6	2	60	120.0	15.5	8.00	42.7	YES	4
7	2	60	120.0	16.1	8.00	41.1	YES	0.3
8	2	60	120.0	16.1	8.10	42.6	YES	1.1
9	2	60	120.0	16.1	8.00	41.1	YES	1.6
10	2	60	120.0	16.6	8.00	39.7	YES	1.2
11								
12								
13	2	60	120.0	16.6	8.00	39.7	YES	2.3
14	2	60	120.0	16.6	8.20	42.8	YES	1.3
15	2	60	120.0	16.6	8.10	41.2	YES	2.2
16	2	60	120.0	16.6	8.10	41.2	YES	1.7
17	2	60	120.0	17.2	8.20	41.1	YES	1.5
18	2	60	120.0	16.1	8.20	44.2	YES	1.5
19	2	60	120.0	16.6	8.20	42.8	YES	1.9
20	2	60	120.0	16.6	8.10	41.2	YES	1.9
21	2	60	120.0	16.6	8.10	41.2	YES	2
22	2	60	120.0	16.6	8.10	41.2	YES	1.5
23	2	60	120.0	16.6	8.10	41.2	YES	3
24	2	60	120.0	16.1	8.20	44.2	YES	1.9
25	2	60	120.0	16.6	8.20	42.8	YES	3.1
26	2	60	120.0	16.6	8.20	42.8	YES	3.2
27	2	60	120.0	17.2	8.20	41.1	YES	1.9
28	2	60	120.0	16.6	8.20	42.8	YES	1.9
29	2	60	120.0	16.6	8.20	42.8	YES	1.8
30	2	60	120.0	15.5	8.20	46.0	YES	2.3
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350