

| OHA - Drinking Water Services -Turbidity Monitoring Report Form | | | | | | | County: | Josephine |
|---|--|------------------|--------------|------------------------------------|------------|--|-------------|-------------------------|
| | | | | | | | Month/Year: | August 2024 |
| System Name: | Morrison's Lodge | | | ID#: 4193508 | | | WTP : TP - | |
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | Highest Reading of the Day 1 [NTU] | | |
| 1 | | | 0.32 | | | | | |
| 2 | | | 0.28 | | | | | |
| 3 | | | 0.16 | | | | | |
| 4 | | | 0.15 | | | | | |
| 5 | | | 0.23 | | | | | |
| 6 | | | 0.22 | | | | | |
| 7 | | | 0.33 | | | | | |
| 8 | | | 0.25 | | | | | |
| 9 | | | 0.58 | | | | | |
| 10 | | | 0.22 | | | | | |
| 11 | | | 0.23 | | | | | |
| 12 | | | 0.16 | | | | | |
| 13 | | | 0.25 | | | | | |
| 14 | | | 0.52 | | | | | |
| 15 | | | 0.36 | | | | | |
| 16 | | | 0.16 | | | | | |
| 17 | | | 0.14 | | | | | |
| 18 | | | 0.21 | | | | | |
| 19 | | | 0.20 | | | | | |
| 20 | | | 0.33 | | | | | |
| 21 | | | 0.29 | | | | | |
| 22 | | | 0.20 | | | | | |
| 23 | | | 0.17 | | | | | |
| 24 | | | 0.15 | | | | | |
| 25 | | | 0.13 | | | | | |
| 26 | | | 0.13 | | | | | |
| 27 | | | 0.16 | | | | | |
| 28 | | | 0.27 | | | | | |
| 29 | | | 0.20 | | | | | |
| 30 | | | 0.20 | | | | | |
| 31 | | | 0.16 | | | | | |
| Conventional or Direct Filtration | | | | Monthly Summary (Answer Yes or No) | | | | |
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? | | | Yes | CT's met everyday? (see back) | | All Cl2 residual at entry point ≥ 0.2 mg/l? | | |
| All 4-hour turbidity readings ≤ 1 NTU? | | | Yes | Yes | | Yes | | |
| All turbidity readings < IFE2 triggers | | | Yes | | | | | |
| Notes: | | | | Trenton Douglas | | | | |
| | | | | Trenton Douglas | | | 9/02/2024 | |
| | | | | 5414799554 | | | CERT #: | |
| <small>1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))</small> | | | | | | | | |
| PAGE 1 of 2 | | | | | | | | |
| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | | | WTP - : | |
| System Name: | Morrison's Lodge | | ID#: 4193508 | August/ 2024 | | Disinfection <i>Giardia</i> Log Inactive: | 1 | |
| Date / Time | Minimum Cl2 Residual at 1st User (C) 3 | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? 3 | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 2 | 60 | 120.0 | 20.6 | 8.20 | 32.8 | YES | 1.3 |

| | | | | | | | | |
|----|---|----|-------|------|------|------|-----|-----|
| 2 | 2 | 60 | 120.0 | 20.6 | 8.20 | 32.8 | YES | 1.4 |
| 3 | 2 | 60 | 120.0 | 23.9 | 8.20 | 26.3 | YES | 3 |
| 4 | 2 | 60 | 120.0 | 22.2 | 8.20 | 29.5 | YES | 2.2 |
| 5 | 2 | 60 | 120.0 | 22.2 | 8.10 | 28.4 | YES | 2.5 |
| 6 | 2 | 60 | 120.0 | 21.1 | 8.20 | 31.7 | YES | 2.1 |
| 7 | 2 | 60 | 120.0 | 21.1 | 8.20 | 31.7 | YES | 2 |
| 8 | 2 | 60 | 120.0 | 21.1 | 8.20 | 31.7 | YES | 1.8 |
| 9 | 2 | 60 | 120.0 | 23.3 | 8.20 | 27.4 | YES | 1.9 |
| 10 | 2 | 60 | 120.0 | 22.2 | 8.20 | 29.5 | YES | 3 |
| 11 | 2 | 60 | 120.0 | 20.6 | 8.20 | 32.8 | YES | 2.5 |
| 12 | 2 | 60 | 120.0 | 20.0 | 8.20 | 34.1 | YES | 3.1 |
| 13 | 2 | 60 | 120.0 | 20.0 | 8.30 | 35.4 | YES | 1.8 |
| 14 | 2 | 60 | 120.0 | 20.0 | 8.20 | 34.1 | YES | 1.5 |
| 15 | 2 | 60 | 120.0 | 20.0 | 8.20 | 34.1 | YES | 1.8 |
| 16 | 2 | 60 | 120.0 | 19.4 | 8.20 | 35.5 | YES | 2.1 |
| 17 | 2 | 60 | 120.0 | 20.0 | 8.20 | 34.1 | YES | 2.3 |
| 18 | 2 | 60 | 120.0 | 19.4 | 8.20 | 35.5 | YES | 1.5 |
| 19 | 2 | 60 | 120.0 | 18.9 | 8.20 | 36.7 | YES | 1.6 |
| 20 | 2 | 60 | 120.0 | 18.9 | 8.20 | 36.7 | YES | 2.6 |
| 21 | 2 | 60 | 120.0 | 18.9 | 8.20 | 36.7 | YES | 1.5 |
| 22 | 2 | 60 | 120.0 | 18.9 | 8.20 | 36.7 | YES | 1.6 |
| 23 | 2 | 60 | 120.0 | 18.9 | 8.20 | 36.7 | YES | 1.2 |
| 24 | 2 | 60 | 120.0 | 17.8 | 8.20 | 39.5 | YES | 2 |
| 25 | 2 | 60 | 120.0 | 17.8 | 8.20 | 39.5 | YES | 2.1 |
| 26 | 2 | 60 | 120.0 | 17.8 | 8.20 | 39.5 | YES | 2.6 |
| 27 | 2 | 60 | 120.0 | 17.2 | 8.30 | 42.6 | YES | 2.5 |
| 28 | 2 | 60 | 120.0 | 17.2 | 8.20 | 41.1 | YES | 1.9 |
| 29 | 2 | 60 | 120.0 | 17.2 | 8.20 | 41.1 | YES | 3 |
| 30 | 2 | 60 | 120.0 | 17.8 | 8.20 | 39.5 | YES | 2.3 |
| 31 | 2 | 60 | 120.0 | 20.0 | 8.20 | 34.1 | YES | 3.1 |

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350