

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Josephine
							Month/Year:	September 2024
System Name:	Morrison's Lodge			ID#: 4193508	WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	Highest Reading of the Day 1 [NTU]		
1			0.25					
2			0.42					
3			0.33					
4			0.21					
5			0.15					
6			0.22					
7			0.21					
8			0.17					
9			0.27					
10			0.28					
11			0.36					
12			0.17					
13			0.16					
14			0.17					
15			0.21					
16			0.30					
17			0.14					
18			0.29					
19			0.16					
20			0.16					
21			0.17					
22			0.22					
23			0.19					
24			0.19					
25			0.44					
26			0.45					
27			0.35					
28			0.15					
29			0.37					
30			0.29					
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE2 triggers				Yes				
Notes:				Trenton Douglas				
				Trenton Douglas			10/6/2024	
				5414799554			CERT #:	
<small>1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))</small>								
PAGE 1 of 2								
OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name:	Morrison's Lodge		ID#: 4193508	September/ 2024			Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2	60	120.0	21.1	8.10	30.5	YES	3

2	2	60	120.0	20.6	8.20	32.8	YES	2.2
3	2	60	120.0	20.6	8.20	32.8	YES	3
4	2	60	120.0	20.6	8.20	32.8	YES	2.8
5	2	60	120.0	18.9	8.20	36.7	YES	3
6	2	60	120.0	19.4	8.20	35.5	YES	2
7	2	60	120.0	21.1	8.20	31.7	YES	2.3
8	2	60	120.0	20.6	8.20	32.8	YES	3
9	2	60	120.0	18.9	8.20	36.7	YES	2.5
10	2	60	120.0	19.4	8.20	35.5	YES	2.3
11	2	60	120.0	18.9	8.20	36.7	YES	4
12	2	60	120.0	18.9	8.20	36.7	YES	2
13	2	60	120.0	18.9	8.20	36.7	YES	3
14	2	60	120.0	17.8	8.20	39.5	YES	2
15	2	60	120.0	17.8	8.20	39.5	YES	3
16	2	60	120.0	18.3	8.20	38.2	YES	2
17	2	60	120.0	18.3	8.20	38.2	YES	2.5
18	2	60	120.0	18.3	8.20	38.2	YES	2.3
19	2	60	120.0	17.2	8.20	41.1	YES	1.5
20	2	60	120.0	17.2	8.20	41.1	YES	2.6
21	2	60	120.0	18.3	8.20	38.2	YES	2.7
22	2	60	120.0	18.3	8.20	38.2	YES	3
23	2	60	120.0	185.3	8.20	-0.8	YES	2.5
24	2	60	120.0	18.3	8.20	38.2	YES	2.4
25	2	60	120.0	18.3	8.20	38.2	YES	2.6
26	2	60	120.0	18.3	8.20	38.2	YES	2.5
27	2	60	120.0	17.8	8.20	39.5	YES	3
28	2	60	120.0	17.8	8.20	39.5	YES	2.6
29	2	60	120.0	17.8	8.20	39.5	YES	2.4
30	2	60	120.0	17.8	8.20	39.5	YES	3

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350