

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Josephine
							Month/Year:	May 2025
System Name:	Morrison's Lodge			ID#: 4193508			WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]		Highest Reading of the Day 1 [NTU]	
1			0.75					
2			0.97					
3			0.56					
4			0.60					
5			0.66					
6			0.57					
7			0.66					
8			0.52					
9			0.77					
10			0.56					
11			0.61					
12			0.86					
13			0.63					
14			0.68					
15			0.90					
16			0.91					
17			0.88					
18			0.84					
19			0.51					
20			0.60					
21			0.53					
22			0.39					
23			0.72					
24			0.86					
25			0.99					
26			0.67					
27			0.72					
28			0.53					
29			0.59					
30			0.53					
31			0.46					
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE2 triggers				Yes				
Notes:				Trenton Douglas				
				Trenton Douglas				
				5414799554				
				06/03/2025				
				06/03/2025				

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Indivd. Filter Effl. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name:	Morrison's Lodge	ID#: 4193508			May/ 2025	Disinfection <i>Giardia</i> Log Inactive:		1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.6	60	96.0	14.0	8.00	45.1	YES	1.2

2	1.6	60	96.0	14.0	8.00	45.1	YES	21.9
3	1	60	60.0	13.3	8.00	44.1	YES	1.1
4	1.2	60	72.0	14.7	8.00	41.1	YES	1.2
5	1.2	60	72.0	13.3	8.00	45.1	YES	2.8
6	1	60	60.0	14.0	8.00	42.1	YES	5
7	1	60	60.0	14.0	8.00	42.1	YES	0.8
8	1.2	60	72.0	14.0	8.00	43.1	YES	0.5
9	1.4	60	84.0	14.0	8.00	44.1	YES	0.8
10	1.4	60	84.0	14.0	8.00	44.1	YES	1
11	1.4	60	84.0	14.0	8.00	44.1	YES	1
12	1.3	60	78.0	14.0	8.00	43.6	YES	0.9
13	1.6	60	96.0	13.8	8.00	45.7	YES	0.5
14	1.9	60	114.0	13.8	8.00	47.3	YES	0.4
15	1.7	60	102.0	14.0	8.00	45.6	YES	0.5
16	1.6	60	96.0	14.3	8.00	44.2	YES	2.5
17	2	60	120.0	14.5	8.00	45.6	YES	3
18	2	60	120.0	15.0	8.00	44.2	YES	2
19	2	60	120.0	14.6	8.00	45.3	YES	0.8
20	2	60	120.0	15.0	8.00	44.2	YES	0.7
21	2	60	120.0	15.0	8.00	44.2	YES	1.1
22	2	60	120.0	15.4	8.00	43.0	YES	1.3
23	2	60	120.0	15.6	8.00	42.4	YES	0.6
24	2	60	120.0	15.3	8.00	43.3	YES	1.2
25	2	60	120.0	15.5	8.00	42.7	YES	1.8
26	2	60	120.0	15.7	8.00	42.2	YES	1.7
27	2	60	120.0	15.8	8.00	41.9	YES	0.8
28	1.8	60	108.0	16.0	8.00	40.4	YES	2.1
29	1.8	60	108.0	17.0	8.00	37.8	YES	0.8
30	1.8	60	108.0	16.8	8.00	38.3	YES	4.2
31	1.9	60	114.0	17.3	8.00	37.5	YES	4.3

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018