

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Jospehine
Conventional or Direct Filtration							Month/Year:	Jun-25
System Name:	Morrisons Rogue River Lodge			ID#: 4193508	WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1			0.47					
2			0.53					
3			0.74					
4			0.64					
5			0.55					
6			0.87					
7			0.57					
8			0.61					
9			0.41					
10			0.55					
11			0.34					
12			0.45					
13			0.49					
14			0.33					
15			0.65					
16			0.35					
17			0.36					
18			0.30					
19			0.26					
20			0.26					
21			0.36					
22			0.30					
23			0.68					
24			0.44					
25			0.42					
26			0.37					
27			0.47					
28			0.52					
29			0.33					
30			0.47					

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	Yes	YES
All turbidity readings < IFE2 triggers	YES		

Notes:	Trenton Douglas	
	Trenton Douglas	07/02/2025
	5414763825	4193508

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name:	Morrisons Rogue River Lodge	ID#: 4193508	Month/Year:	October/2024	Disinfection Giardia Log Inactive:		1	
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	I	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.0	60	120.0	17.5	8.00	39.5	Yes	4
2	2.0	60	120.0	17	8.00	39.5	yes	1.5
3	2.0	60	120.0	17	8.00	39.5	yes	1.8

4	2.0	60	120.0	17	8.00	39.5	yes	0.9
5	2.0	60	120.0	17.3	8.00	39.5	yes	4.5
6	2.0	60	120.0	1708	8.00	39.5	yes	5.2
7	2.0	60	120.0	18.1	8.00	39.5	yes	3
8	2.0	60	120.0	18.5	8.00	39.5	yes	6
9	2.0	60	120.0	17.8	8.00	39.5	yes	0.8
10	2.0	60	120.0	17.9	8.00	39.5	yes	0.9
11	2.2	60	132.0	19	8.10	39.5	yes	4.3
12	2.0	60	120.0	18.2	8.10	39.5	yes	3.5
13	2.0	60	120.0	18.1	8.10	39.5	yes	1.4
14	2.4	60	144.0	17.2	8.20	39.5	yes	2.8
15	2.2	60	132.0	17.4	8.20	39.5	yes	1.2
16	2.2	60	132.0	17.9	8.10	39.5	yes	2.2
17	2.0	60	120.0	18	8.10	39.5	yes	1.4
18	2.0	60	120.0	18.2	8.10	39.5	yes	7.9
19	2.0	60	120.0	17.2	8.10	0.9	yes	8.4
20	2.0	60	120.0	16.4	8.20	79.0	yes	0.9
21	2.0	60	120.0	16.9	8.20	79.0	yes	1.6
22	2.0	60	120.0	15.9	8.20	58.0	yes	5.9
23	2.0	60	120.0	16.5	8.20	58.0	yes	2.2
24	2.0	60	120.0	16.5	8.10	58.0	yes	3.1
25	2.0	60	120.0	17	8.10	58.0	yes	3
26	2.0	60	120.0	18	8.10	79.0	yes	2.8
27	1.8	60	108.0	18.1	8.10	58.0	yes	2.8
28	2.0	60	120.0	18.5	8.10	58.0	yes	2.1
29	1.6	60	96.0	18.5	8.10	36.0	yes	1.3
30	1.4	60	84.0	18.7	8.10	58.0	yes	2.2

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350