

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Josephine

Month/Year: July 2025

System Name:		Morrison's Lodge		ID#: 4193508		WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1			0.37				
2			0.59				
3			0.60				
4			0.39				
5			0.31				
6			0.31				
7			0.28				
8			0.28				
9			0.33				
10			0.27				
11			0.29				
12			0.33				
13			0.25				
14			0.41				
15			0.75				
16			0.32				
17			0.30				
18			0.30				
19			0.24				
20			0.33				
21			0.36				
22			0.30				
23			0.39				
24			0.28				
25			0.24				
26			0.23				
27			0.31				
28			0.29				
29			0.24				
30			0.22				
31			0.36				

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE2 triggers	Yes		

Notes:	Trenton Douglas	
	Trenton Douglas	08/03/2025
	5414799554	08/03/2025

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:		Morrison's Lodge		ID#: 4193508		July/ 2025		Disinfection <i>Giardia</i> Log Inactive:		1	
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow			
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]			
1	1.8	60	108.0	19.0	8.10	34.3	YES	1.5			

2	1.8	60	108.0	19.6	8.10	33.0	YES	1.5
3	1.8	60	108.0	19.5	8.10	33.2	YES	2.2
4	1.6	60	96.0	19.3	8.20	34.2	YES	1
5	1.8	60	108.0	19.4	8.20	34.7	YES	2.6
6	2	60	120.0	19.4	8.20	35.5	YES	2.1
7	2	60	120.0	19.2	8.20	36.0	YES	2.3
8	2.2	60	132.0	19.5	8.20	36.1	YES	2.5
9	2.2	60	132.0	20.2	8.20	34.4	YES	1.3
10	2.2	60	132.0	20.0	8.10	33.6	YES	2.1
11	2	60	120.0	20.7	8.10	31.4	YES	4.2
12	2	60	120.0	20.5	8.10	31.8	YES	2.5
13	2	60	120.0	20.9	8.10	31.0	YES	1.3
14	2	60	120.0	21.7	8.10	29.3	YES	2
15	2	60	120.0	21.5	8.10	29.7	YES	2.2
16	2	60	120.0	21.8	8.10	29.2	YES	1.8
17	2	60	120.0	22.0	8.10	28.8	YES	1.6
18	1.6	60	96.0	21.7	8.20	29.1	YES	1.3
19	1.8	60	108.0	21.2	8.20	30.8	YES	1.4
20	2	60	120.0	21.5	8.10	29.7	YES	2.2
21	2	60	120.0	21.1	8.10	30.5	YES	2.1
22	2	60	120.0	20.9	8.10	31.0	YES	1.9
23	1.8	60	108.0	21.0	8.20	31.2	YES	1.7
24	1.6	60	96.0	20.5	8.20	31.5	YES	2.1
25	1.8	60	108.0	20.4	8.20	32.5	YES	3
26	1.8	60	108.0	20.5	8.20	32.3	YES	2
27	2	60	120.0	20.3	8.20	33.4	YES	2.6
28	1.8	60	108.0	21.6	8.20	30.0	YES	2.1
29	1.5	60	90.0	21.7	8.20	28.8	YES	2.3
30	2	60	120.0	22.5	8.20	28.9	YES	2.3
31	2	60	120.0	21.7	8.20	30.5	YES	3.2

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.