

OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Josephine
							Month/Year:	August 2025
System Name:	Morrison's Lodge			ID#: 4193508			WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]		Highest Reading of the Day 1 [NTU]	
1			0.28					
2			0.39					
3			0.26					
4			0.28					
5			0.28					
6			0.32					
7			0.26					
8			0.53					
9			0.23					
10			0.20					
11			0.32					
12			0.23					
13			0.27					
14			0.27					
15			0.25					
16			0.79					
17			0.40					
18			0.26					
19			0.31					
20			0.31					
21			0.24					
22			0.21					
23			0.42					
24			0.20					
25			0.44					
26			0.22					
27			0.38					
28			0.26					
29			0.21					
30			0.22					
31			0.46					
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?			Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?		
All 4-hour turbidity readings $\leq$ 1 NTU?			Yes	Yes		Yes		
All turbidity readings < IFE2 triggers			Yes					
Notes:				Trenton Douglas				
				Trenton Douglas				
				5414799554				
				Sept. 7, 2025				
				CERT #:				

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Indivd. Filter Effl. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name:	Morrison's Lodge	ID#: 4193508	August/ 2025				Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.7	60	102.0	21.5	8.20	29.8	YES	3

2	1.7	60	102.0	21.5	8.20	29.8	YES	1.2
3	2	60	120.0	20.8	8.20	32.3	YES	2.8
4	2	60	120.0	20.8	8.20	32.3	YES	2.9
5	2	60	120.0	20.2	8.20	33.7	YES	2
6	2	60	120.0	20.1	8.20	33.9	YES	3.5
7	2	60	120.0	20.7	8.20	32.6	YES	2
8	2	60	120.0	21.0	8.20	31.9	YES	4
9	1.9	60	114.0	20.1	8.20	33.5	YES	3.5
10	2	60	120.0	21.3	8.20	31.3	YES	4.6
11	2	60	120.0	21.3	8.20	31.3	YES	2.8
12	2	60	120.0	21.1	8.20	31.7	YES	3.3
13	2	60	120.0	22.2	8.20	29.5	YES	3.4
14	2	60	120.0	21.4	8.20	31.1	YES	4.5
15	1.7	60	102.0	20.7	8.20	31.5	YES	3.5
16	2	60	120.0	21.6	8.30	31.8	YES	4.1
17	2	60	120.0	21.1	8.20	31.7	YES	3.2
18	2	60	120.0	21.2	8.20	31.5	YES	3.6
19	1.8	60	108.0	21.3	8.20	30.6	YES	3.3
20	1.8	60	108.0	21.0	8.20	31.2	YES	3.4
21	2	60	120.0	20.5	8.20	33.0	YES	2.1
22	1.6	60	96.0	21.1	8.20	30.3	YES	3.8
23	1.6	60	96.0	22.5	8.20	27.6	YES	3.5
24	1.6	60	96.0	22.7	8.20	27.2	YES	4.9
25	2	60	120.0	22.5	8.20	28.9	YES	4.7
26	2	60	120.0	22.4	8.20	29.1	YES	3.9
27	2	60	120.0	22.3	8.20	29.3	YES	1.8
28	2	60	120.0	20.3	8.20	33.4	YES	4.6
29	2	60	120.0	20.7	8.30	33.8	YES	5.8
30	1.8	60	108.0	20.3	8.30	33.9	YES	4.9
31	1.9	60	114.0	20.4	8.20	32.8	YES	4.7

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350