

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Josephine**
 Month/Year: **September 2025**

System Name:		Morrison's Lodge		ID#: 4193508		WTP: TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1			0.26				
2			0.25				
3			0.18				
4			0.37				
5			0.22				
6			0.18				
7			0.16				
8			0.29				
9			0.27				
10			0.37				
11			0.30				
12			0.19				
13			0.29				
14			0.75				
15			0.39				
16			0.27				
17			0.43				
18			0.60				
19			0.58				
20			0.35				
21			0.30				
22			0.21				
23			0.20				
24			0.47				
25			0.38				
26			0.33				
27			0.37				
28			0.36				
29			0.39				
30			0.49				
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?				Yes		CT's met everyday? (see back)	
All 4-hour turbidity readings ≤ 1 NTU?				Yes		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All turbidity readings < IFE2 triggers				Yes		Yes	
Notes:				Trenton Douglas			
				Trenton Douglas			
				10/01/2025			
				5414799554			

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-081-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:		Morrison's Lodge		ID#: 4193508		September/ 2025		WTP - :	
								Disinfection <i>Giardia</i> Log Inactive:	
								1	

Date / Time	Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	2	60	120.0	20.7	8.20	32.6	YES	4

2	2	60	120.0	20.5	8.20	33.0	YES	2.5
3	2	60	120.0	21.4	8.30	32.2	YES	1.5
4	2	60	120.0	21.0	8.20	31.9	YES	0.8
5	2	60	120.0	21.0	8.30	33.1	YES	1.2
6	2	60	120.0	21.4	8.20	31.1	YES	3
7	2	60	120.0	21.0	8.20	31.9	YES	4.2
8	2	60	120.0	20.6	8.20	32.8	YES	4.4
9	2	60	120.0	20.2	8.20	33.7	YES	1.8
10	1.8	60	108.0	19.8	8.20	33.8	YES	0.7
11	2	60	120.0	20.0	8.20	34.1	YES	0.7
12	2	60	120.0	19.4	8.30	36.8	YES	2.8
13	2	60	120.0	19.7	8.30	36.1	YES	4.2
14	1.8	60	108.0	19.5	8.20	34.5	YES	4
15	1.8	60	108.0	18.9	8.30	37.2	YES	1.2
16	2	60	120.0	18.3	8.30	39.6	YES	1.9
17	2	60	120.0	19.5	8.20	35.3	YES	3.8
18	2	60	120.0	18.9	8.30	38.1	YES	1.8
19	1.9	60	114.0	19.0	8.30	37.4	YES	2.2
20	1.9	60	114.0	19.0	8.20	36.0	YES	4.2
21	2	60	120.0	19.0	8.30	37.8	YES	4.4
22	2	60	120.0	19.2	8.20	36.0	YES	1.3
23	1.6	60	96.0	19.0	8.20	34.8	YES	2.5
24	1.6	60	96.0	17.7	8.20	38.0	YES	1
25	1.8	60	108.0	17.9	8.20	38.3	YES	1.2
26	1.9	60	114.0	17.5	8.30	41.3	YES	3.4
27	1.9	60	114.0	17.0	8.20	41.2	YES	2.4
28	1.9	60	114.0	18.0	8.20	38.5	YES	2.4
29	2	60	120.0	18.0	8.20	39.0	YES	1.8
30	2	60	120.0	19.3	8.20	35.7	YES	1.3

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.