

System Name: Hellgate River Lodge ID# 41 93512

WTP ID

| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|---|
| 1 | | | | 31 | | |
| 2 | 41 | 0 | 41 | | .046 | .046 |
| 3 | 41 | 0 | 41 | | .046 | .046 |
| 4 | 41 | 0 | 41 | | .046 | .046 |
| 5 | | | | | | |
| 6 | ← not open → | | | | | |
| 7 | | | | | | |
| 8 | | | | | | |
| 9 | | | | | | |
| 10 | 30 | 25 | 5 | | .045 | .045 |
| 11 | 49 | 0 | 49 | | .046 | .045 |
| 12 | 30 | 25 | 5 | | .047 | .047 |
| 13 | | | | | | |
| 14 | ← not open → | | | | | |
| 15 | | | | | | |
| 16 | | | | | | |
| 17 | 42 | 0 | 42 | | .045 | .045 |
| 18 | 30 | 30 | 0 | | .045 | .045 |
| 19 | 48 | 0 | 48 | | .046 | .046 |
| 20 | 30 | 30 | 0 | | .046 | .046 |
| 21 | ← not open → | | | | | |
| 22 | 20 | 20 | 0 | | .046 | .046 |
| 23 | ← not open → | | | | | |
| 24 | 40 | 0 | 40 | | .046 | .046 |
| 25 | 31 | 31 | 0 | | .048 | .048 |
| 26 | 27 | 22 | 5 | | .048 | .048 |
| 27 | 32 | 0 | 32 | | .048 | .048 |
| 28 | 41 | 0 | 41 | | .048 | .048 |
| 29 | ← not open → | | | | | |
| 30 | 20 | 18 | 2 | | .047 | .047 |
| 31 | 47 | 0 | 47 | | .048 | .048 |

Cartridge & Bag Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's speci

PRINTED NAME: Jared Leonard

SIGNATURE: [Signature]

DATE: June 10, 2024

PHONE #: (541) 621-8478

CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading Column may not correspond to continuous readings maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

Name: Hellgate River Lodge ID #41 93512 WTP:- Month/Year May / 2024

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) 3 | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|-------------|--|------------------|-----------|-------|-----|-------------|----------------------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | Use tables | Yes / No | [GPM] |
| 1 | | 152 | | | | | | 10 |
| 2 | .6 | | 91.2 | 13.7 | 7.4 | 43 | Y | 10 |
| 3 | .6 | | 91.2 | 15 | 6.6 | 24 | Y | 10 |
| 4 | .6 | | 91.2 | 15 | 6.7 | 24 | Y | 10 |
| 5 | | | | | | | | 10 |
| 6 | | | | | | | | 10 |
| 7 | | | | | | | | 10 |
| 8 | | | | | | | | 10 |
| 9 | | | | | | | | 10 |
| 10 | .6 | | 91.2 | 19.3 | 7.0 | 24 | Y | 10 |
| 11 | .6 | | 91.2 | 19.8 | 6.9 | 24 | Y | 10 |
| 12 | .8 | | 121.6 | 19.8 | 6.9 | 24 | Y | 10 |
| 13 | | | | | | | | 10 |
| 14 | | | | | | | | 10 |
| 15 | | | | | | | | 10 |
| 16 | | | | | | | | 10 |
| 17 | .6 | | 91.2 | 19.3 | 7.0 | 24 | Y | 10 |
| 18 | .6 | | 91.2 | 18.5 | 7.0 | 24 | Y | 10 |
| 19 | .6 | | 91.2 | 19.5 | 7.0 | 24 | Y | 10 |
| 20 | .6 | | 91.2 | 19.4 | 7.1 | 29 | Y | 10 |
| 21 | | | | | | | | 10 |
| 22 | .6 | | 91.2 | 17.1 | 7.1 | 29 | Y | 10 |
| 23 | | | | | | | | 10 |
| 24 | .6 | | 91.2 | 21.9 | 7.0 | 18 | Y | 10 |
| 25 | .6 | | 91.2 | 18.1 | 7.0 | 24 | Y | 10 |
| 26 | .8 | | 121.6 | 18.4 | 7.0 | 24 | Y | 10 |
| 27 | .8 | | 121.6 | 18.2 | 7.0 | 24 | Y | 10 |
| 28 | .7 | | 106.4 | 18.3 | 7.0 | 24 | Y | 10 |
| 29 | | | | | | | | 10 |
| 30 | .7 | | 106.4 | 20.0 | 7.0 | 18 | Y | 10 |
| 31 | .8 | | 121.6 | 19.2 | 6.9 | 24 | Y | 10 |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Revised November 2022
Return by 10th of following month by email, fax, or mail to:

Month:

Year: *MAY 2024*

Hellgate River Lodge
Meter Record Sheet

93512

| | | | | | | |
|----------------|----------------|----------------|---------------------------------|----------------|----------------|----------------|
| 1 | 2 | 3 | 4 | 5 | 6 | 7 |
| | <i>1040661</i> | <i>1044184</i> | <i>10445146</i> | | | |
| 8 | 9 | 10 | 11 | 12 | 13 | 14 |
| | | <i>1047418</i> | <i>1049273</i> | <i>1053325</i> | | |
| 15 | 16 | 17 | 18 | 19 | 20 | 21 |
| | | <i>1059716</i> | <i>1060462</i> | <i>1063751</i> | <i>1064920</i> | |
| 22 | 23 | 24 | 25 | 26 | 27 | 28 |
| <i>1067132</i> | | <i>1072275</i> | <i>1073389</i> | <i>1078257</i> | <i>1079421</i> | <i>1082890</i> |
| 29 | 30 | 31 | Monthly Total H2O Usage Reading | | | |
| | <i>1086000</i> | <i>1088339</i> | <i>47678</i> | | | |