

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Cartridge or Bag Filtration

County: Josephine
Month/Year: May 2025

System Name: HELLEGATE RIVER LODGE		ID# 41 93512		WTP ID:		
DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading the Day [NTU]
1						
2						
3						
4						
5						
6						
7						
8	26	25	5		.013	.013
9	28	24	5.5		.012	.012
10	26	25	5		.013	.013
11	26	25	5		.013	.013
12						
13						
14						
15	28	24	5.5		.012	.012
16	30	25	5		.012	.012
17	26	25	5		.015	.015
18	26	25	5		.013	.013
19						
20						
21						
22	28	25	5.5		.013	.013
23	30	24	6		.012	.012
24	13	0	13		.012	.012
25	25	20	5		.012	.012
26	26	24	5		.013	.013
27						
28						
29	26	22	6		.013	.013
30	28	21	7		.012	.012
31	8	6	8		.014	.014

Cartridge Filtration
Monthly Summary

95% of daily turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
All daily turbidity readings $\leq$ 5 NTU? ☒ Yes / ☐ No

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)

* PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

Monthly Summary (Answer Yes or No)

CT's met everyday? ☒ Yes / ☐ No
(see back)

All Cl₂ residual at entry point $\geq$ 0.2 mg/L? ☒ Yes / ☐ No

PRINTED NAME: Stephayne Dailey

SIGNATURE: *Stephayne Dailey*

DATE: 6/9/25

PHONE #: (541) 218-6686

CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form - *Giardia* Inactivation

Name: HELLGATE RIVER LODGE ID #41: 93512 WTP-: May 2025 Month/Year: May 2025 Log Requirement (Circle One): 0.5 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hour Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /		152					Y	10
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /	.7		121.4	17.6	7.0	24	Y	8
9 /	.8		121.5	17.7	7.1	28		
10 /	.8		121.6	17.7	7.2	29		
11 /	.8		121.6	17.7	7.2	29		
12 /								
13 /								
14 /								
15 /	.8		121.4	17.5	7.1	28		
16 /	.8		121.6	17.7	7.2	29		
17 /	.8		121.6	17.2	7.0	24		
18 /	.8		121.5	17.3	7.0	24		
19 /								
20 /								
21 /								
22 /	.8		121.6	17.4	7.3	27		
23 /	.8		121.6	17.4	7.4	29		
24 /	.8		121.6	21.3	7.0	18		
25 /	.8		121.6	19.2	6.9	24		
26 /	.8		121.4	18.5	7.0	24		
27 /								
28 /								
29 /	.8		121.5	19.2	7.0	24		
30 /	.8		121.6	19.9	7.0	24		
31 /	.8		121.6	21.2	6.9	18		

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Month: MAY

Year: 2025

Hellgate River Lodge
Meter Record Sheet

93512

1	2	3	4	5	6	7
		NO SERVICE				
8	9	10	11	12	13	14
1,789,484	1791339	1793273	1795381	X	X	X
15	16	17	18	19	20	21
1794963	1798532	1800640		X	X	X
22	23	24	25	26	27	28
1803321	1805868	1808638	1812140	1813318	X	X
29	30	31	Monthly Total H2O Usage Reading			
1815164	1817011	1817111				

X = NO SERVICE