

OHA - Drinking Water Services - Surface Water Quality Data Form

County: JOSEPHINE

Month/Year: Jun-25

Cartridge or Bag Filtration

System Name: HELLGATE RIVER LODGE ID#: 41 93512 WTP ID: A TP- For Rogue River

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	28.00	22.00	6.00		0.01	0.01
2	32.00	25.00	7.00		0.01	0.01
3	33.00	25.00	8.00		0.01	0.01
4	30.00	24.00	6.00		0.01	0.01
5	28.00	22.00	6.00		0.01	0.01
6	28.00	22.00	6.00		0.01	0.01
7	32.00	25.00	7.00		0.01	0.01
8	9.00	0.00	9.00		0.02	0.02
9	12.00	0.00	12.00		0.01	0.01
10	30.00	24.00	6.00		0.01	0.01
11	29.00	22.00	7.00		0.01	0.01
12	31.00	24.00	7.00		0.01	0.01
13	30.00	24.00	6.00		0.01	0.01
14	29.00	22.00	7.00		0.01	0.01
15	31.00	23.00	8.00		0.01	0.01
16	32.00	24.00	8.00		0.01	0.01
17	4.00	0.00	4.00		0.01	0.01
18	25.00	20.00	5.00		0.01	0.01
19	25.00	20.00	5.00		0.01	0.01
20	30.00	24.00	6.00		0.01	0.01
21	30.00	25.00	5.00		0.01	0.01
22	0.00	0.00	0.00		0.01	0.01
23	0.00	0.00	0.00		0.01	0.01
24	22.00	15.00	7.00		0.01	0.01
25	23.00	15.00	8.00		0.01	0.01
26	0.00	0.00	0.00		0.01	0.01
27	20.00	16.00	4.00		0.01	0.01
28	30.00	25.00	5.00		0.01	0.01
29	35.00	28.00	7.00		0.01	0.01
30	30.00	25.00	5.00		0.01	0.01
31	30.00	24.00	6.00		0.01	0.01

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

Yes / No

All daily turbidity readings $\leq$ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point $\geq$ 0.2
mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's
specifications when to change the filter, at what PSID.

PRINTED NAME: STEPHAYNE DAILEY

SIGNATURE: *Stephayne Dailey*

DATE: 7/9/25

PHONE #: (541) 479-7204

CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

PAGE 1 of 2

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-A TP for

Rogue R

System Name:

HELLGATE RIVER LODGE

ID#: 41

93512

Month/Year:

Jun-25

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	152	121.6	21.8	6.90	16.2	YES	
2	1.4	152	212.8	20.9	7.00	19.2	YES	
3	1.4	152	212.8	21.3	6.90	18.0	YES	
4	1.4	152	212.8	21.3	7.00	18.7	YES	
5	1.4	152	212.8	21.5	7.00	18.4	YES	
6	1.4	152	212.8	22.5	7.00	17.2	YES	
7	1.2	152	182.4	23.4	7.10	16.4	YES	
8	1.4	152	212.8	23.6	7.00	16.0	YES	
9	1.4	152	212.8	23.7	7.10	16.5	YES	
10	1.4	152	212.8	21.2	7.00	18.8	YES	
11	1.2	152	182.4	23.1	7.10	16.7	YES	
12	1.2	152	182.4	23.8	7.20	16.6	YES	
13	1.2	152	182.4	21.4	7.10	18.8	YES	
14	0.8	152	121.6	20.7	7.00	18.1	YES	
15	0.8	152	121.6	20.9	7.00	17.9	YES	
16	1.4	152	212.8	21.3	7.10	19.4	YES	
17	1.4	152	212.8	21.8	7.10	18.7	YES	
18	1.4	152	212.8	20.8	7.20	20.8	YES	
19	1.4	152	212.8	19.5	7.00	21.1	YES	
20	1.4	152	212.8	19.5	7.00	21.1	YES	
21	1.2	152	182.4	18.7	7.00	21.7	YES	
22	0.8	152	121.6	19.4	7.00	19.8	YES	
23	1	152	152.0	20.9	7.10	19.0	YES	
24	0.6	152	91.2	23.0	7.00	15.1	YES	
25	0.6	152	91.2	21.3	6.90	16.4	YES	
26	0.8	152	121.6	22.0	7.00	16.6	YES	
27	0.8	152	121.6	22.2	7.30	18.3	YES	
28	0.8	152	121.6	23.1	7.00	15.4	YES	
29	1.4	152	212.8	23.4	7.10	16.8	YES	
30	1.4	152	212.8	23.5	7.10	16.7	YES	
31	1.4	152	212.8	23.4	7.10	16.8	YES	

Month:	June
Year:	2025
1	2
1821856	18241648
8	9
1840237	1843191
15	16
1860024	1864515
22	23
1883926	1886962
29	30
1912054	1904627

Hellgate River Lodge

Meter Record Sheet

3	4	5	6	7
1826587	182927325	1830966	1832295	1837081
10	11	12	13	14
1845416	1847679	1849866	1853827	1855466
17	18	19	20	21
1867397	1870195	1872923	1877990	1880283
24	25	26	27	28
1889205	1887463	1913241	1902697	1907246
31	Monthly Total H2O Reading			
1893271				