

OHA - Drinking Water Services - Surface Water Quality Data Form

County: JOSEPHINE

Cartridge or Bag Filtration

Month/Year: Jul-25

System Name: HELLGATE RIVER LODGE ID#: 41 93512 WTP ID: A TP: For Rogue River

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	28.00	26.00	2.00		0.01	0.01
2	32.00	31.00	1.00		0.01	0.01
3	32.00	32.00	0.00		0.01	0.01
4	33.00	31.00	2.00		0.01	0.01
5	26.00	24.00	2.00		0.01	0.01
6	0.00	0.00	0.00		0.01	0.01
7	28.00	28.00	0.00		0.01	0.01
8	26.00	24.00	2.00		0.01	0.01
9	0.00	0.00	0.00		0.01	0.01
10	32.00	28.00	4.00		0.01	0.01
11	26.00	24.00	2.00		0.01	0.01
12	19.00	15.00	4.00		0.01	0.01
13	29.00	24.00	5.00		0.01	0.01
14	0.00	0.00	0.00		0.03	0.03
15	0.00	0.00	0.00		0.01	0.01
16	19.00	15.00	4.00		0.01	0.01
17	26.00	26.00	0.00		0.01	0.01
18	30.00	28.00	2.00		0.01	0.01
19	27.00	27.00	0.00		0.01	0.01
20	20.00	18.00	2.00		0.01	0.01
21	24.00	23.00	1.00		0.01	0.01
22	31.00	30.00	1.00		0.01	0.01
23	27.00	26.00	1.00		0.02	0.02
24	0.00	0.00	0.00		0.01	0.01
25	30.00	30.00	0.00		0.01	0.01
26	30.00	30.00	0.00		0.01	0.01
27	35.00	35.00	0.00		0.01	0.01
28	22.00	21.00	1.00		0.01	0.01
29	30.00	30.00	0.00		0.01	0.01
30	13.00	0.00	13.00		0.01	0.01
31						

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

Yes / No

All daily turbidity readings $\leq$ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)All Cl2 residual at entry point $\geq$ 0.2 mg/l?

Yes / No

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: STEPHAYNE DAILEY

SIGNATURE:

DATE: 08/09/2025

PHONE #: (541) 479-7204

CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-A TP for

Rogue R

System Name: HELLGATE RIVER LODGE

ID#: 41

93512

Month/Year:

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.4	152	212.8	24.3	7.30	17.0	YES	10
2	1.4	152	212.8	23.1	7.30	18.5	YES	10
3	1.4	152	212.8	29.0	7.30	12.3	YES	10
4	1.6	152	243.2	29.0	7.20	12.2	YES	10
5	1.6	152	243.2	24.2	7.10	16.3	YES	10
6	1.5	152	228.0	24.8	6.90	14.3	YES	10
7	1.4	152	212.8	24.8	7.10	15.3	YES	10
8	1.2	152	182.4	24.8	7.10	14.9	YES	10
9	1.2	152	182.4	28.1	7.40	13.3	YES	10
10	1.4	152	212.8	28.2	7.10	12.1	YES	10
11	0.8	152	121.6	25.0	7.90	19.0	YES	10
12	1.2	152	182.4	25.1	7.80	19.0	YES	10
13	1.4	152	212.8	26.1	7.40	15.7	YES	10
14	1.4	152	212.8	26.5	7.40	15.2	YES	10
15	1.2	152	182.4	26.0	7.60	16.6	YES	10
16	1	152	152.0	26.4	7.50	15.2	YES	10
17	1.2	152	182.4	25.9	7.80	18.0	YES	10
18	1.3	152	197.6	25.7	7.30	15.3	YES	10
19	1.4	152	212.8	26.0	7.50	16.4	YES	10
20	1.4	152	212.8	25.0	7.50	17.5	YES	10
21	1.2	152	182.4	24.5	7.20	15.8	YES	10
22	1.4	152	212.8	26.7	7.70	16.9	YES	10
23	1.4	152	212.8	26.5	7.70	17.1	YES	10
24	1.6	152	243.2	26.0	7.70	18.1	YES	10
25	1.4	152	212.8	28.0	6.90	11.3	YES	10
26	1.2	152	182.4	27.0	7.10	12.8	YES	10
27	1.2	152	182.4	27.0	7.50	14.9	YES	10
28	1.4	152	212.8	28.0	7.30	13.2	YES	10
29	1.4	152	212.8	27.0	6.80	11.7	YES	10
30	1.2	152	182.4	26.2	7.10	13.5	YES	10
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Month: July
Year: 2025

Hellgate River Lodge
Meter Record Sheet

1	2	3	4	5	6	7
1917864	1922032	1925673	1928745	1932941	1935974	1938371
8	9	10	11	12	13	14
1947132	1944641	1953157	1954556	1957619	1965447	1964311
15	16	17	18	19	20	21
1968327	1970489.5	1972639	1975321	1977805	1981570	1984697.9
22	23	24	25	26	27	28
1992369	1996432	1998481	2001839	2006421	2013154	2015727
29	30	31	Monthly Total H2O Reading			
2018443	2022177.2					