

OHA - Drinking Water Services - Surface Water Quality Data Form

County: JOSEPHINE

Cartridge or Bag Filtration

Month/Year: Aug 2025

System Name: HELLGATE RIVER LODGE ID#: 41 93512 WTP ID: A TP- For Rogue River

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	9	0	9		.016	.016
2	35	35	0		.014	.014
3	5	8	5		.013	.013
4	0	0	0		.015	.015
5	35	34	1		.015	.015
6	0	0	0		.016	.016
7	0	0	0		.015	.015
8	8	0	8		.016	.016
9	30	30	0		.014	.014
10	3	0	3		.013	.013
11	29	25	5		.015	.015
12	30	25	5		.015	.015
13	30	28	2		.013	.013
14	30	28	2		.014	.014
15	35	35	0		.014	.014
16	30	30	0		.014	.014
17	30	30	0		.014	.014
18	34	32	2		.013	.013
19	34	32	2		.013	.013
20	30	30	0		.012	.012
21	31	31	0		.012	.012
22	30	25	5		.013	.013
23	30	25	5		.013	.013
24	34	27	7		.013	.013
25	32	28	4		.012	.012
26	32	28	4		.012	.012
27	31	30	1		.014	.014
28	31	28	3		.014	.014
29	30	28	2		.013	.013
30	35	30	5		.013	.013
31	15	0	15		.012	.012

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

Yes / No

All daily turbidity readings $\leq$ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point $\geq$ 0.2
mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's
specifications when to change the filter, at what PSID.

PRINTED NAME: STEPHAYNE DAILEY

SIGNATURE: Stanley

DATE: 9/5/25

PHONE #: (541) 479-7204

CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: HELLGATE RIVER LODGE

ID#: 41 93512

Month/Year: Aug 2025

WTP-A TP for

Rogue R

Disinfection
Giardia Log
Inactiv:

0.5
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	152	192.4	26.0	7.8	18	Y	10
2	1.4		212.8	25.0	7.5	16	Y	
3	1.4		212.8	25.4	7.5	16	Y	
4	1.2		182.4	24.8	7.8	28	Y	
5			152	24	7.3	26	Y	
6	1.0		152	25	7.5	15	Y	
7	.8		121.6	24.7	7.6	26	Y	
8	.8		121.6	24.7	7.7	25	Y	
9	1.0		152	24.1	7.5	22	Y	
10	1.0		152	24.9	7.5	22	Y	
11	1.0		152	24.8	7.4	21	Y	
12	1.0		152	24.8	7.4	21	Y	
13	1.0		152	29	7.7	18	Y	
14	1.2		182.4	28	7.7	17	Y	
15	.8		121.6	24.7	7.6	26	Y	
16	1.2		182.4	24.9	7.5	23	Y	
17	1.2		182.4	24.2	7.5	23	Y	
18	1.0		152	29	7.7	18	Y	
19	1.0		152	29	7.7	18	Y	
20	.8		121.6	24.7	7.6	26	Y	
21	1.0		152	24.7	7.6	26	Y	
22	.8		121.6	24.9	7.7	26	Y	
23	1.2		182.4	24.9	7.5	23	Y	
24	1.2		182.4	24.8	7.5	23	Y	
25	1.2		182.4	24.8	7.5	23	Y	
26	1.0		152	24.7	7.6	26	Y	
27	1.0		152	24.7	7.6	26	Y	
28	.8		121.6	24.8	7.6	26	Y	
29	.8		121.6	24.8	7.6	26	Y	
30	1.0		152	24.7	7.7	27	Y	
31	1.0		152	24.6	7.7	27	Y	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

Revised November 2022

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Aug 2025

Hellgate River Lodge

Meter Record Sheet

Month: Aug							
Year: 2025							
1	2	3	4	5	6	7	
2031451	2035356	2040668	20432533	20461537.5	2049068	2051831	
8	9	10	11	12	13	14	
2054928	2059360	2064565	20660873	2069126	2072699	2076425	
15	16	17	18	19	20	21	
2081292	2085802	2091582	2094110	20960879	2100143	2103595	
22	23	24	25	26	27	28	
2107462	2112762	2117982	2120418	2123271	2126458	2129603	
29	30	31	Monthly Total H2O Reading				
2133668	2138053	2143396					