

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Jun-21

CT MET	DAY	PSI	PSI	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.22		
YES	2	55	54	1	15, 15	0.43		
YES	3	53	52	1	15, 15	0.52		
YES	4	51	50	1	15, 15	0.32		
YES	5	50	49	1	15, 15	0.36		
YES	6	55	54	1	15, 15	0.39		
YES	7	56	55	1	15, 15	0.53		
YES	8	52	51	1	15, 15	0.32		
YES	9	53	52	1	15, 15	0.45		
YES	10	55	54	1	15, 15	0.57		
YES	11	53	52	1	15, 15	0.52		
YES	12	49	48	1	15, 15	0.19		
NO	13	55	54	1	15, 15	0.28	Boil Notice in effect	
NO	14	52	51	1	15, 15	0.26		
NO	15	56	55	1	15, 15	0.27		
NO	16	55	54	1	15, 15	0.25		
YES	17	50	49	1	15, 15	0.35		
YES	18	50	49	1	15, 15	0.34		
YES	19	53	52	1	15, 15	0.33		
YES	20	52	51	1	15, 15	0.30		
YES	21	52	51	1	15, 15	0.30		
YES	22	51	50	1	15, 15	0.35		
YES	23	50	49	1	15, 15	0.39		
YES	24	55	54	1	15, 15	0.38		
YES	25	54	53	1	15, 15	0.42		
YES	26	55	54	1	15, 15	0.33		
YES	27	55	54	1	15, 15	0.31		
YES	28	53	52	1	15, 15	0.36		
YES	29	53	52	1	15, 15	0.36		
YES	30	52	51	1	15, 15	0.34		
95% of Daily Turbidity Readings < 1 ntu Yes							CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L NO	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? NO	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 7/7/2021 CERT # 3675

