

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 Minikahda Water District PWS ID# 4193609  
 TURBIDITY MONITORING REPORT FORM

MT/YR Nov-21

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	56	55	1	15, 15	0.50		
YES	2	54	53	1	15, 15	0.40		
YES	3	55	54	1	15, 15	0.60		
YES	4	55	54	1	15, 15	0.40		
YES	5	55	54	1	15, 15	0.51		
YES	6	55	54	1	15, 15	0.39		
YES	7	55	54	1	15, 15	0.42		
YES	8	56	55	1	15, 15	0.37		
YES	9	56	55	1	15, 15	0.46		
YES	10	55	54	1	15, 15	0.29		
YES	11	55	54	1	15, 15	0.54		
YES	12	55	54	1	15, 15	0.43		
YES	13	55	54	1	15, 15	0.58		
YES	14	55	54	1	15, 15	0.74		
YES	15	55	54	1	15, 15	0.55		
YES	16	55	54	1	15, 15	0.38		
YES	17	55	54	1	15, 15	0.54		
YES	18	52	51	1	15, 15	0.34		
YES	19	53	52	1	15, 15	0.34		
YES	20	54	53	1	15, 15	0.42		
YES	21	52	51	1	15, 15	0.53		
YES	22	57	56	1	15, 15	0.32		
YES	23	55	54	1	15, 15	0.39		
YES	24	55	54	1	15, 15	0.46		
YES	25	54	53	1	15, 15	0.36		
YES	26	55	54	1	15, 15	0.37		
YES	27	51	50	1	15, 15	0.41		
YES	28	55	54	1	15, 15	0.66		
YES	29	53	52	1	15, 15	0.52		
YES	55	50	49	1	15, 15	0.38		
							CL <sub>2</sub> RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob  
 PRINT NAME David Jacob  
 DATE 12/1/2021 CERT # 3675

