

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 Minikahda Water District PWS ID# 4193609  
 TURBIDITY MONITORING REPORT FORM

MT/YR Feb-22

CT MET	DAY	PSI	PSI	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.43		
YES	2	54	53	1	15, 15	0.33		
YES	3	55	54	1	15, 15	0.43		
YES	4	54	53	1	15, 15	0.47		
YES	5	52	51	1	15, 15	0.28		
YES	6	50	49	1	15, 15	0.37		
YES	7	55	54	1	15, 15	0.34		
YES	8	54	53	1	15, 15	0.38		
YES	9	54	53	1	15, 15	0.41		
YES	10	50	49	1	15, 15	0.58		
YES	11	55	54	1	15, 15	0.37		
YES	12	54	53	1	15, 15	0.37		
YES	13	55	54	1	15, 15	0.29		
YES	14	54	53	1	15, 15	0.38		
YES	15	52	51	1	15, 15	0.35		
YES	16	55	54	1	15, 15	0.37		
YES	17	50	49	1	15, 15	0.29		
YES	18	50	49	1	15, 15	0.37		
YES	19	48	47	1	15, 15	0.28		
YES	20	48	47	1	15, 15	0.44		
YES	21	49	48	1	15, 15	0.29		
YES	22	50	49	1	15, 15	0.34		
YES	23	50	49	1	15, 15	0.38		
YES	24	45	44	1	15, 15	0.28		
YES	25	50	49	1	15, 15	0.35		
YES	26	54	53	1	15, 15	0.3		
YES	27	55	54	1	15, 15	0.36		
YES	28	55	54	1	15, 15	0.45		
95% of Daily Turbidity Readings < 1 ntu Yes							CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob  
 PRINT NAME David Jacob

DATE 3/9/2022 CERT # 3675

