

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Apr-22

CT MET	DAY	PSI	PSID	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	50	49	1	15, 15	0.26		
YES	2	51	50	1	15, 15	0.18		
YES	3	52	51	1	15, 15	0.36		
YES	4	52	51	1	15, 15	0.52		
YES	5	51	50	1	15, 15	0.42		
YES	6	50	49	1	15, 15	0.38		
YES	7	51	50	1	15, 15	0.42		
YES	8	51	50	1	15, 15	0.55		
YES	9	50	49	1	15, 15	0.28		
YES	10	50	49	1	15, 15	0.45		
YES	11	50	49	1	15, 15	0.29		
YES	12	50	49	1	15, 15	0.32		
YES	13	50	49	1	15, 15	0.26		
YES	14	53	52	1	15, 15	0.29		
YES	15	53	52	1	15, 15	0.42		
YES	16	51	50	1	15, 15	0.37		
YES	17	51	50	1	15, 15	0.48		
YES	18	52	51	1	15, 15	0.51		
YES	19	52	51	1	15, 15	0.38		
YES	20	52	51	1	15, 15	0.33		
YES	21	52	51	1	15, 15	0.38		
YES	22	53	52	1	15, 15	0.21		
YES	23	52	51	1	15, 15	0.38		
YES	24	53	52	1	15, 15	0.36		
YES	25	53	52	1	15, 15	0.41		
YES	26	54	53	1	15, 15	0.36		
YES	27	53	52	1	15, 15	0.41		
YES	28	49	48	1	15, 15	0.35		
YES	29	49	48	1	15, 15	0.29		
YES	30	49	48	1	15, 15	0.34		
							CL ₂ RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 5/3/2022 CERT # 3675

