

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Oct-22

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity	HIGHEST READING	
YES/NO						NTU	NTU	
YES	1	50	49	1	15, 15	0.35		
YES	2	49	48	1	15, 15	0.36		
YES	3	52	51	1	15, 15	0.45		
YES	4	55	54	1	15, 15	0.30		
YES	5	52	51	1	15, 15	0.28		
YES	6	55	54	1	15, 15	0.26		
YES	7	50	49	1	15, 15	0.24		
YES	8	55	54	1	15, 15	0.25		
YES	9	51	50	1	15, 15	0.35		
YES	10	58	57	1	15, 15	0.35		
YES	11	52	51	1	15, 15	0.34		
YES	12	55	54	1	15, 15	0.26		
YES	13	54	53	1	15, 15	0.26		
YES	14	55	54	1	15, 15	0.27		
YES	15	51	50	1	15, 15	0.37		
YES	16	55	54	1	15, 15	0.35		
YES	17	48	47	1	15, 15	0.42		
YES	18	49	48	1	15, 15	0.33		
YES	19	55	54	1	15, 15	0.39		
YES	20	52	51	1	15, 15	0.30		
YES	21	55	54	1	15, 15	0.40		
YES	22	52	51	1	15, 15	0.55		
YES	23	53	52	1	15, 15	0.32		
YES	24	55	54	1	15, 15	0.56		
YES	25	51	50	1	15, 15	0.45		
YES	26	52	51	1	15, 15	0.54		
YES	27	55	54	1	15, 15	0.35		
YES	28	51	50	1	15, 15	0.62		
YES	29	48	47	1	15, 15	0.52		
YES	30	52	51	1	15, 15	0.57		
YES	31	51	50	1	15, 15	0.45		
95% of Daily Turbidity Readings < 1 ntu						Yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L	Yes
All Daily Turbidity Readings < 5 NTU						Yes	CT's Met Everyday?	Yes

phone 503-310-9262

SIGNATURE: David Jacob

PRINT NAME David Jacob

DATE 11/2/2022 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Oct-22

DATE	TIME	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW
		PPM	minutes	C x T	C°		Equation	GPM
10/1/22	12:00	1.30	123	160	10	7.4	46	6.3
10/2/22	15:30	1.30	134	174	10	7.4	46	5.8
10/3/22	12:00	1.30	120	156	10	7.4	46	6.5
10/4/22	15:00	1.30	116	150	11	7.4	43	6.7
10/5/22	18:00	1.30	122	159	11	7.5	45	6.4
10/6/22	16:20	1.30	132	172	11	7.4	43	5.9
10/7/22	11:00	1.30	119	154	11	7.4	43	6.6
10/8/22	18:30	1.30	122	158	11	7.5	45	6.4
10/9/22	17:30	1.30	138	179	11	7.5	45	5.6
10/10/22	13:15	1.30	140	182	10	7.4	46	5.6
10/11/22	16:20	1.30	140	181	10	7.4	46	5.6
10/12/22	16:00	1.30	157	204	10	7.5	48	5.0
10/13/22	16:45	1.30	256	333	10	7.5	48	3.0
10/14/22	16:45	1.30	231	300	10	7.4	46	3.4
10/15/22	17:00	1.30	202	263	10	7.4	46	3.9
10/16/22	18:45	1.30	194	252	10	7.5	48	4.0
10/17/22	16:45	1.30	248	322	9	7.4	49	3.1
10/18/22	17:00	1.30	251	326	9	7.4	49	3.1
10/19/22	18:00	1.30	249	324	9	7.4	49	3.1
10/20/22	18:45	1.30	249	324	9	7.4	49	3.1
10/21/22	16:00	1.30	255	332	9	7.5	51	3.1
10/22/22	17:15	1.30	209	272	9	7.5	51	3.7
10/23/22	17:00	1.30	214	278	8	7.4	52	3.6
10/24/22	17:45	1.00	235	235	8	7.5	53	3.3
10/25/22	14:15	1.00	147	147	7	7.4	54	5.3
10/26/22	15:45	1.30	348	453	7	7.5	58	2.2
10/27/22	15:00	1.30	335	435	7	7.5	58	2.3
10/28/22	16:30	1.30	290	376	7	7.5	58	2.7
10/29/22	16:30	1.30	276	358	7	7.4	56	2.8
10/30/22	15:45	1.30	314	408	7	7.4	56	2.5
10/31/22	17:00	1.30	240	312	7	7.4	56	3.3