

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Feb-22

CT MET	DAY	PSI	PSI	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	49	48	1	15, 15	0.34		
YES	2	49	48	1	15, 15	0.39		
YES	3	48	47	1	15, 15	0.25		
YES	4	45	44	1	15, 15	0.35		
YES	5	52	51	1	15, 15	0.39		
YES	6	51	50	1	15, 15	0.34		
YES	7	50	49	1	15, 15	0.43		
YES	8	45	44	1	15, 15	0.42		
YES	9	48	47	1	15, 15	0.35		
YES	10	46	45	1	15, 15	0.32		
YES	11	48	47	1	15, 15	0.36		
YES	12	52	51	1	15, 15	0.31		
YES	13	51	50	1	15, 15	0.35		
YES	14	53	52	1	15, 15	0.35		
YES	15	52	51	1	15, 15	0.65		
YES	16	51	50	1	15, 15	0.34		
YES	17	54	53	1	15, 15	0.03	new turb meter	
YES	18	52	51	1	15, 15	0.04		
YES	19	52	51	1	15, 15	0.03		
YES	20	49	48	1	15, 15	0.08		
YES	21	50	49	1	15, 15	0.03		
YES	22	50	49	1	15, 15	0.02		
YES	23	52	51	1	15, 15	0.03		
YES	24	52	51	1	15, 15	0.04		
YES	25	48	47	1	15, 15	0.03		
YES	26	48	47	1	15, 15	0.03		
YES	27	46	45	1	15, 15	0.03		
YES	28	45	44	1	15, 15	0.03		
95% of Daily Turbidity Readings < 1 ntu Yes							CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 3/4/2023 CERT # 3675

