

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Apr-22

CT MET	DAY	PSI	PSID	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	49	48	1	15, 15	0.07		
YES	2	45	44	1	15, 15	0.08		
YES	3	51	50	1	15, 15	0.08		
YES	4	52	51	1	15, 15	0.07		
YES	5	52	51	1	15, 15	0.07		
YES	6	51	50	1	15, 15	0.07		
YES	7	50	49	1	15, 15	0.07		
YES	8	49	48	1	15, 15	0.09		
YES	9	48	47	1	15, 15	0.08		
YES	10	47	46	1	15, 15	0.15		
YES	11	49	48	1	15, 15	0.17		
YES	12	48	47	1	15, 15	0.22		
YES	13	49	48	1	15, 15	0.17		
YES	14	50	49	1	15, 15	0.16		
YES	15	52	51	1	15, 15	0.15		
YES	16	52	51	1	15, 15	0.18		
YES	17	53	52	1	15, 15	0.17		
YES	18	54	53	1	15, 15	0.14		
YES	19	51	50	1	15, 15	0.13		
YES	20	50	49	1	15, 15	0.16		
YES	21	51	50	1	15, 15	0.17		
YES	22	52	51	1	15, 15	0.15		
YES	23	50	49	1	15, 15	0.17		
YES	24	49	48	1	15, 15	0.16		
YES	25	48	47	1	15, 15	0.15		
YES	26	48	47	1	15, 15	0.22		
YES	27	46	45	1	15, 15	0.16		
YES	28	52	51	1	15, 15	0.15		
YES	29	51	50	1	15, 15	0.19		
YES	30	54	53	1	15, 15	0.15		
				0				
95% of Daily Turbidity Readings < 1 ntu Yes							CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 5/6/2023 CERT # 3675

