

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 Minikahda Water District PWS ID# 4193609  
 TURBIDITY MONITORING REPORT FORM

MT/YR Jun-23

CT MET	DAY	PSI	PSI	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	48	47	1	15, 15	0.11		
YES	2	44	43	1	15, 15	0.14		
YES	3	46	45	1	15, 15	0.15		
YES	4	48	47	1	15, 15	0.10		
YES	5	49	48	1	15, 15	0.14		
YES	6	50	49	1	15, 15	0.15		
YES	7	51	50	1	15, 15	0.09		
YES	8	51	50	1	15, 15	0.10		
YES	9	55	54	1	15, 15	0.55		
YES	10	54	53	1	15, 15	0.12		
YES	11	52	51	1	15, 15	0.15		
YES	12	49	48	1	15, 15	0.17		
YES	13	47	46	1	15, 15	0.10		
YES	14	50	49	1	15, 15	0.17		
YES	15	50	49	1	15, 15	0.11		
YES	16	52	51	1	15, 15	0.10		
YES	17	52	51	1	15, 15	0.06		
YES	18	49	48	1	15, 15	0.06		
YES	19	49	48	1	15, 15	0.05		
YES	20	48	47	1	15, 15	0.05		
YES	21	48	47	1	15, 15	0.05		
YES	22	48	47	1	15, 15	0.04		
YES	23	49	48	1	15, 15	0.04		
YES	24	47	46	1	15, 15	0.04		
YES	25	46	45	1	15, 15	0.04		
YES	26	50	49	1	15, 15	0.04		
YES	27	50	49	1	15, 15	0.04		
YES	28	48	47	1	15, 15	0.04		
YES	29	48	47	1	15, 15	0.04		
YES	30	46	45	1	15, 15	0.03		
95% of Daily Turbidity Readings < 1 ntu Yes							CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob  
 PRINT NAME David Jacob

DATE 7/6/2023 CERT # 3675

