

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 Minikahda Water District PWS ID# 4193609  
 TURBIDITY MONITORING REPORT FORM

MT/YR Sep-23

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	49.8	49.7	0.1	15, 15	0.13		
YES	2	49.9	49.9	0	15, 15	0.12		
YES	3	48.5	48.5	0	15, 15	0.13		
YES	4	49.8	49.8	0	15, 15	0.13		
YES	5	49.2	49.1	0.1	15, 15	0.13		
YES	6	51.4	51.3	0.1	15, 15	0.13		
YES	7	51.5	51.3	0.2	15, 15	0.13		
YES	8	50.3	50.2	0.1	15, 15	0.13		
YES	9	51.6	51.5	0.1	15, 15	0.13		
YES	10	48.4	48.3	0.1	15, 15	0.13		
YES	11	50.5	50.3	0.2	15, 15	0.13		
YES	12	51.8	51.8	0	15, 15	0.14		
YES	13	50.4	50.4	0	15, 15	0.15		
YES	14	50	49.8	0.2	15, 15	0.15		
YES	15	50.5	50.5	0	15, 15	0.16		
YES	16	51.5	51.4	0.1	15, 15	0.15		
YES	17	49.1	49	0.1	15, 15	0.14		
YES	18	50.5	50.4	0.1	15, 15	0.15		
YES	19	51.4	51.4	0	15, 15	0.15		
YES	20	49.6	49.5	0.1	15, 15	0.15		
YES	21	51.3	51.2	0.1	15, 15	0.16		
YES	22	50.7	50.7	0	15, 15	0.16		
YES	23	49.5	49.4	0.1	15, 15	0.16		
YES	24	49.2	49.2	0	15, 15	0.16		
YES	25	50.2	50.1	0.1	15, 15	0.16		
YES	26	49.4	49.3	0.1	15, 15	0.16		
YES	27	54.9	54.7	0.2	15, 15	0.16		
YES	28	50.3	50.3	0	15, 15	0.16		
YES	29	49	48.9	0.1	15, 15	0.16		
YES	30	53.2	53.1	0.1	15, 15	0.16		
							CL <sub>2</sub> RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob  
 PRINT NAME David Jacob  
 DATE 10/1/2023 CERT # 3675

