

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 Minikahda Water District PWS ID# 4193609  
 TURBIDITY MONITORING REPORT FORM

MT/YR Nov-23

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	49.4	49.3	0.1	15, 15	0.05		
YES	2	49.7	49.6	0.1	15, 15	0.12		
YES	3	52.4	52.4	0	15, 15	0.26		
YES	4	49.6	49.5	0.1	15, 15	0.16		
YES	5	51.2	51.1	0.1	15, 15	0.34		
YES	6	52.8	52.8	0	15, 15	0.52		
YES	7	48.2	48	0.2	15, 15	0.21		
YES	8	53.3	53.2	0.1	15, 15	0.14		
YES	9	53.2	53.1	0.1	15, 15	0.09		
YES	10	53.3	53	0.3	15, 15	0.12		
YES	11	49	48.9	0.1	15, 15	0.12		
YES	12	50.8	50.9	-0.1	15, 15	0.08		
YES	13	48.9	48.7	0.2	15, 15	0.10		
YES	14	52.7	52.6	0.1	15, 15	0.05		
YES	15	53.4	53.2	0.2	15, 15	0.07		
YES	16	48.8	48.6	0.2	15, 15	0.11		
YES	17	48.4	48.2	0.2	15, 15	0.07		
YES	18	52.8	52.7	0.1	15, 15	0.06		
YES	19	49.1	48.8	0.3	15, 15	0.10		
YES	20	51.1	50.9	0.2	15, 15	0.08		
YES	21	52	51.9	0.1	15, 15	0.05		
YES	22	48.5	48.4	0.1	15, 15	0.09		
YES	23	48.2	48	0.2	15, 15	0.06		
YES	24	49	48.8	0.2	15, 15	0.07		
YES	25	48.5	48.3	0.2	15, 15	0.06		
YES	26	48.4	48.2	0.2	15, 15	0.06		
YES	27	48.9	48.7	0.2	15, 15	0.06		
YES	28	49	48.8	0.2	15, 15	0.05		
YES	29	54.2	54.1	0.1	15, 15	0.06		
YES	55	53.6	53.4	0.2	15, 15	0.09		
							CL <sub>2</sub> RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob  
 PRINT NAME David Jacob  
 DATE 12/2/2023 CERT # 3675

