

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Mar-24

DAY	PSI	PSI	PSID	PSI when	Daily Turbidit		HIGHEST READING
					NTU		NTU
1	54.8	54.7	0.1	15, 15	0.06		
2	53	52.9	0.1	15, 15	0.05		
3	52.5	52.5	0	15, 15	0.13		
4	53.5	53.3	0.2	15, 15	0.05		
5	53.5	53.3	0.2	15, 15	0.08		
6	53.7	53.6	0.1	15, 15	0.09		
7	53.4	53.2	0.2	15, 15	0.03		
8	53.9	53.7	0.2	15, 15	0.03		
9	51.1	50.9	0.2	15, 15	0.08		
10	52.6	52.4	0.2	15, 15	0.06		
11	54.2	54	0.2	15, 15	0.03		
12	54	53.8	0.2	15, 15	0.09		
13	54.8	54.6	0.2	15, 15	0.03		
14	53.9	53.7	0.2	15, 15	0.03		
15	51	50.9	0.1	15, 15	0.09		
16	53.3	53.2	0.1	15, 15	0.04		
17	49.9	49.8	0.1	15, 15	0.03		
18	53.3	53.1	0.2	15, 15	0.07		
19	53.3	53.1	0.2	15, 15	0.05		
20	53.1	53	0.1	15, 15	0.05		
21	53.1	53	0.1	15, 15	0.05		
22	53.5	53.4	0.1	15, 15	0.04		
23	52.3	52.2	0.1	15, 15	0.04		
24	51.5	51.4	0.1	15, 15	0.09		
25	51.1	50.9	0.2	15, 15	0.06		
26	52.6	52.5	0.1	15, 15	0.05		
27	51.4	51.1	0.3	15, 15	0.1		
28	49.4	49.3	0.1	15, 15	0.09		
29	46.6	46.4	0.2	15, 15	0.07		
30	51.8	51.5	0.3	15, 15	0.2		
31	55	54.8	0.2	15, 15	0.04		
95% of Daily Turbidity Readings < 1 ntu Yes						CL ₂ RESID AT Entry Point yes	
All Daily Turbidity Readings < 5 NTU Yes						CT's Met Everyday? Yes	

310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 4/1/2024 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Mar-24

DATE	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
3/1/24	1.20	329	395	2.2	7.1	34	3.5	YES
3/2/24	1.20	306	367	2.2	7.1	34	4.8	YES
3/3/24	1.30	312	406	2.0	7.1	36	4.5	YES
3/4/24	1.19	335	398	1.8	7.1	35	3.1	YES
3/5/24	1.11	343	380	1.8	7.1	35	2.7	YES
3/6/24	1.09	333	361	1.5	7.1	36	3.3	YES
3/7/24	1.09	330	359	1.6	7.1	35	3.4	YES
3/8/24	1.21	310	376	1.5	7.1	36	4.5	YES
3/9/24	1.40	293	410	1.9	7.2	37	5.5	YES
3/10/24	1.54	288	444	2.0	7.3	39	5.8	YES
3/11/24	1.54	322	494	2.2	7.3	38	3.9	YES
3/12/24	1.50	318	476	2.1	7.3	38	4.1	YES
3/13/24	1.38	330	456	1.9	7.3	38	3.4	YES
3/14/24	1.16	332	384	1.5	7.2	38	3.3	YES
3/15/24	1.17	305	357	1.8	7.2	37	4.8	YES
3/16/24	1.33	316	419	2.2	7.3	37	4.2	YES
3/17/24	1.47	295	434	2.3	7.3	38	5.4	YES
3/18/24	1.44	333	480	2.8	7.3	36	3.2	YES
3/19/24	1.43	302	430	3.1	7.3	36	5.0	YES
3/20/24	1.43	331	474	3.6	7.3	34	3.3	YES
3/21/24	1.43	336	481	3.5	7.3	34	3.0	YES
3/22/24	1.42	329	468	3.4	7.3	35	3.5	YES
3/23/24	1.43	300	429	3.6	7.3	34	5.2	YES
3/24/24	1.42	307	436	3.6	7.2	34	4.8	YES
3/25/24	1.36	289	393	3.7	7.2	33	5.8	YES
3/26/24	1.23	318	392	3.7	7.2	33	4.1	YES
3/27/24	1.17	324	379	3.8	7.2	32	3.8	YES
3/28/24	1.12	229	255	3.6	7.2	32	9.3	YES
3/29/24	1.08	307	331	3.4	7.2	32	4.7	YES
3/30/24	1.14	309	352	3.2	7.2	33	4.6	YES
3/31/24	1.21	307	371	3.7	7.2	32	4.8	YES