

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas

TURBIDITY MONITORING REPORT MT/YR CT req'd
FORM Sep-24 0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	35.2	35.1	0.1	15, 15	0.23	
2	37.6	37.5	0.1	15, 15	0.15	
3	44.8	44.8	0	15, 15	0.08	
4	42.1	42.1	0	15, 15	0.07	
5	41.9	41.8	0.1	15, 15	0.46	
6	38.9	38.9	0	15, 15	0.19	
7	41.3	41.2	0.1	15, 15	0.12	
8	42.6	42.5	0.1	15, 15	0.3	
9	44.1	44	0.1	15, 15	0.17	
10	44.2	44.1	0.1	15, 15	0.1	
11	43.9	43.8	0.1	15, 15	0.55	
12	41.4	41.4	0	15, 15	0.16	
13	41.5	41.4	0.1	15, 15	0.12	
14	37.9	39.9	-2	15, 15	0.46	
15	39.8	39.8	0	15, 15	0.07	
16	37.9	41.7	-3.8	15, 15	0.46	
17	44.7	44.6	0.1	15, 15	0.1	
18	43.1	43.1	0	15, 15	0.09	
19	42.9	42.8	0.1	15, 15	0.09	
20	39.8	39.8	0	15, 15	0.42	
21	39.7	39.8	-0.1	15, 15	0.14	
22	42.9	42.8	0.1	15, 15	0.06	
23	43.6	43.5	0.1	15, 15	0.43	
24	38.5	38.5	0	15, 15	0.11	
25	40.5	40.5	0	15, 15	0.09	
26	43.6	43.7	-0.1	15, 15	0.49	
27	39.8	39.9	-0.1	15, 15	0.12	
28	43.2	43.2	0	15, 15	0.08	
29	44.1	44.1	0	15, 15	0.48	
30	43.2	43.2	0	15, 15	0.04	
			0			
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

5-Oct

CERT #

3675

