

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas

TURBIDITY MONITORING REPORT
FORM

MT/YR

CT req'd

Nov-24

0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	35.8	35.8	0	15, 15	0.24	
2	31.7	31.6	0.1	15, 15	0.3	
3	34.3	34.3	0	15, 15	0.41	
4	34.7	34.7	0	15, 15	0.44	
5	33.5	33.5	0	15, 15	0.21	
6	34.4	34.3	0.1	15, 15	0.19	
7	21.9	22.1	-0.2	15, 15	0.16	
8	34.6	34.6	0	15, 15	0.17	
9	45.8	45.8	0	15, 15	0.08	
10	42.3	42.1	0.2	15, 15	0.12	
11	39.6	39.6	0	15, 15	0.06	
12	49.3	49.2	0.1	15, 15	0.1	
13	42.8	42.7	0.1	15, 15	0.11	
14	49.5	49.4	0.1	15, 15	0.12	
15	43.3	43.1	0.2	15, 15	0.16	
16	42.8	42.8	0	15, 15	0.11	
17	47.1	46.9	0.2	15, 15	0.16	
18	43.3	43.1	0.2	15, 15	0.24	
19	43.7	43.6	0.1	15, 15	0.14	
20	43.2	43.2	0	15, 15	0.2	
21	55.5	55.2	0.3	15, 15	0.09	
22	48.7	48.6	0.1	15, 15	0.14	
23	53.4	53.3	0.1	15, 15	0.11	
24	51.3	51.1	0.2	15, 15	0.09	
25	48	48	0	15, 15	0.15	
26	53.8	53.6	0.2	15, 15	0.07	
27	54.7	54.6	0.1	15, 15	0.06	
28	48.7	48.4	0.3	15, 15	0.1	
29	52.6	52.4	0.2	15, 15	0.05	
30	47.2	47.1	0.1	15, 15	0.1	
			0			
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

12/2/2024

CERT #

3675

