

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Feb-25 0.5

DAY	PSI	PSI	PSID	when to	Turbidity		
					NTU		
1	49.5	49.2	0.3	15, 15	0.11		
2	48.3	48	0.3	15, 15	0.2		
3	53.9	53.7	0.2	15, 15	0.07		
4	54.8	54.7	0.1	15, 15	0.06		
5	47.7	47.6	0.1	15, 15	0.18		
6	54.4	54.3	0.1	15, 15	0.04		
7	52.9	52.6	0.3	15, 15	0.03		
8	48.6	48.4	0.2	15, 15	0.14		
9	52	51.8	0.2	15, 15	0.03		
10	48.6	48.4	0.2	15, 15	0.1		
11	48	47.8	0.2	15, 15	0.09		
12	53.8	53.5	0.3	15, 15	0.04		
13	52.8	52.6	0.2	15, 15	0.04		
14	47	46.9	0.1	15, 15	0.11		
15	46.4	46.3	0.1	15, 15	0.11		
16	51.5	51.2	0.3	15, 15	0.04		
17	50.4	50.4	0	15, 15	0.14		
18	51.8	51.7	0.1	15, 15	0.11		
19	53	52.8	0.2	15, 15	0.11		
20	47.9	47.6	0.3	15, 15	0.24		
21	49.2	49	0.2	15, 15	0.09		
22	49.3	49.1	0.2	15, 15	0.07		
23	46.7	46.5	0.2	15, 15	0.25		
24	49.8	49.7	0.1	15, 15	0.83		
25	40.6	39	1.6	15, 15	1.32		
26	47.3	47.2	0.1	15, 15	0.99		
27	20.2	20.2	0	15, 15	0.95		
28	20.2	20.1	0.1	15, 15	0.2		
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point	yes		
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?	yes		

310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob
 DATE _____ CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Feb-25

DATE	E RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
2/1/25	1.50	324	485	1.8	7.65	45	3.8	YES
2/2/25	1.49	297	442	1.68	7.62	45	5.3	YES
2/3/25	1.24	323	401	1.56	7.57	43	3.8	YES
2/4/25	1.23	331	408	1.37	7.58	44	3.3	YES
2/5/25	1.20	315	378	1.31	7.58	44	4.3	YES
2/6/25	1.22	315	385	1.19	7.62	45	4.3	YES
2/7/25	1.20	280	336	1.13	7.59	44	6.3	YES
2/8/25	1.22	293	357	1.19	7.62	45	5.5	YES
2/9/25	1.21	302	366	1.19	7.6	45	5.0	YES
2/10/25	1.25	320	399	0.89	7.62	46	4.0	YES
2/11/25	0.99	317	315	0.21	7.54	45	4.2	YES
2/12/25	0.69	318	221	0.03	7.44	43	4.1	YES
2/13/25	0.60	301	180	0.03	7.38	41	5.1	YES
2/14/25	0.64	307	195	0.09	7.47	43	4.7	YES
2/15/25	0.88	290	255	0.46	7.56	44	5.7	YES
2/16/25	1.17	292	343	0.57	7.65	47	5.6	YES
2/17/25	1.21	296	359	0.85	7.65	46	5.4	YES
2/18/25	1.15	306	350	1.01	7.57	44	4.8	YES
2/19/25	1.13	318	358	1.19	7.53	43	4.1	YES
2/20/25	1.14	303	345	1.5	7.57	43	5.0	YES
2/21/25	1.24	252	311	1.5	7.62	44	8.0	YES
2/22/25	1.37	288	394	1.8	7.68	45	5.8	YES
2/23/25	1.42	269	383	2.14	7.69	44	7.0	YES
2/24/25	1.34	307	410	1.99	7.56	42	4.8	YES
2/25/25	0.94	319	301	2.17	7.07	33	4.0	YES
2/26/25	0.97	308	298	2.11	7.09	34	4.7	YES
2/27/25	0.59	313	184	2.6	7.17	32	4.4	YES
2/28/25	0.59	305	180	2.5	7.25	33	4.9	YES

phone 503-