

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
Minikahda Water District PWS ID# 4193609
TURBIDITY MONITORING REPORT FORM

MT/YR Mar-25

DAY	PSI	PSI	PSID	when to	Turbidity		HIGHEST READING
					NTU		NTU
1	41.7	40.9	0.8	15, 15	0.6		
2	42.4	42.3	0.1	15, 15	0.16		
3	42.4	42.3	0.1	15, 15	0.46		
4	43.6	43.5	0.1	15, 15	0.29		
5	50.2	49.9	0.3	15, 15	0.21		
6	51.1	51	0.1	15, 15	0.57		
7	48	47.5	0.5	15, 15	0.84		
8	49.1	49	0.1	15, 15	0.29		
9	49.2	49	0.2	15, 15	0.15		
10	47.3	47.1	0.2	15, 15	0.22		
11	48	47.9	0.1	15, 15	0.06		
12	46.2	46.2	0	15, 15	0.13		
13	47.8	47.6	0.2	15, 15	0.22		
14	49.8	49.5	0.3	15, 15	0.05		
15	50.8	50.7	0.1	15, 15	0.05		
16	47.5	47.4	0.1	15, 15	0.11		
17	39.5	39.4	0.1	15, 15	0.13		
18	48.1	48	0.1	15, 15	0.1		
19	47	47	0	15, 15	0.09		
20	49.6	49.4	0.2	15, 15	0.05		
21	50.1	49.9	0.2	15, 15	0.05		
22	44.4	44.3	0.1	15, 15	0.09		
23	48.1	47.9	0.2	15, 15	0.07		
24	47.2	47	0.2	15, 15	0.07		
25	46.6	46.5	0.1	15, 15	0.09		
26	48.1	48	0.1	15, 15	0.06		
27	45.3	45.1	0.2	15, 15	0.11		
28	45.5	45.3	0.2	15, 15	0.12		
29	44.9	44.8	0.1	15, 15	0.06		
30	46.1	46	0.1	15, 15	0.05		
31	47	46.9	0.1	15, 15	0.11		
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point		yes	
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes	

310-9262

SIGNATURE: David Jacob
PRINT NAME David Jacob

DATE 4/2/2025 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
Minikahda Water District PWS ID# 4193609
SURFACE WATER QUALITY DATA

Mar-25

DATE	INE RESID	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
3/1/25	1.45	294	425	3.4	7.3	36	5.5	YES
3/2/25	1.60	307	490	3.9	7.4	36	4.8	YES
3/3/25	1.50	307	461	3.8	7.4	36	4.7	YES
3/4/25	1.93	326	628	3.6	7.4	38	3.6	YES
3/5/25	1.95	312	607	3.1	7.4	40	4.5	YES
3/6/25	1.88	313	588	2.6	7.3	39	4.4	YES
3/7/25	1.83	301	551	2.7	7.2	38	5.1	YES
3/8/25	1.89	305	575	2.7	7.3	39	4.9	YES
3/9/25	2.00	295	588	2.8	7.3	40	5.5	YES
3/10/25	2.05	308	631	3.3	7.3	38	4.7	YES
3/11/25	2.00	303	607	3.4	7.3	38	5.0	YES
3/12/25	1.86	317	590	3.6	7.3	36	4.2	YES
3/13/25	1.75	323	566	2.9	7.3	37	3.8	YES
3/14/25	1.53	327	501	2.6	7.2	36	3.6	YES
3/15/25	1.52	315	480	3.1	7.2	35	4.3	YES
3/16/25	1.52	305	464	3.1	7.2	35	4.9	YES
3/17/25	1.55	252	391	2.9	7.2	35	7.9	YES
3/18/25	1.29	330	425	2.7	7.2	35	3.4	YES
3/19/25	1.28	317	405	2.8	7.1	34	4.2	YES
3/20/25	1.29	320	415	3.1	7.1	33	4.0	YES
3/21/25	1.33	309	411	2.8	7.2	34	4.6	YES
3/22/25	1.41	294	416	2.7	7.2	35	5.5	YES
3/23/25	1.48	292	431	3.2	7.2	34	5.6	YES
3/24/25	1.47	293	431	3.9	7.1	32	5.5	YES
3/25/25	1.39	300	418	3.7	7.1	32	5.1	YES
3/26/25	1.12	295	331	4.1	7.0	29	5.4	YES
3/27/25	1.10	302	331	4.2	7.0	29	5.0	YES
3/28/25	1.11	289	320	4.0	7.1	30	5.8	YES
3/29/25	1.10	299	328	3.8	7.1	30	5.2	YES
3/30/25	1.04	295	306	3.7	7.1	30	5.4	YES
3/31/25	1.04	310	321	4.2	7.1	30	4.6	YES

phone 503-