

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas

TURBIDITY MONITORING REPORT
FORM

MT/YR _____ CT req'd

Aug-25 0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	46.3	46.3	0.0	15, 15	0.065	
2	38.8	38.7	0.0	15, 15	0.085	
3	42.2	42.2	0.0	15, 15	0.185	
4	43.5	43.5	0.0	15, 15	0.068	
5	46.0	46.0	0.0	15, 15	0.058	
6	45.0	45.0	0.0	15, 15	0.080	
7	44.4	44.5	0.0	15, 15	0.412	
8	43.0	42.9	0.1	15, 15	0.355	
9	46.4	46.4	0.0	15, 15	0.268	
10	39.3	39.3	0.0	15, 15	0.130	
11	42.7	42.6	0.1	15, 15	0.105	
12	44.3	44.3	0.0	15, 15	0.230	
13	41.8	41.7	0.1	15, 15	0.208	
14	43.4	43.3	0.1	15, 15	0.095	
15	46.6	46.5	0.1	15, 15	0.260	
16	43.6	43.5	0.0	15, 15	0.103	
17	43.0	43.2	-0.1	15, 15	0.148	
18	44.0	44.0	0.0	15, 15	0.623	
19	39.9	39.8	0.1	15, 15	0.275	
20	37.1	37.1	0.0	15, 15	0.093	
21	41.4	41.3	0.1	15, 15	0.088	
22	43.1	43.1	0.1	15, 15	0.248	
23	40.7	40.9	-0.2	15, 15	0.243	
24	37.9	38.0	-0.1	15, 15	0.083	
25	35.2	35.1	0.0	15, 15	0.195	
26	43.1	43.1	0.0	15, 15	0.083	
27	44.2	44.2	0.0	15, 15	0.070	
28	45.6	45.6	-0.1	15, 15	0.250	
29	42.2	42.1	0.1	15, 15	0.065	
30	34.0	34.0	0.0	15, 15	0.050	
31	39.6	39.7	-0.1	15, 15	0.210	
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

1-Sep-25

CERT #

3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
Minikahda Water District PWS ID# 4193609
SURFACE WATER QUALITY DATA

Aug-25

DATE	INE RESID	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
8/1/25	1.28	269	344	12.6	6.9	16	7.0	YES
8/2/25	1.28	229	293	12.0	6.9	17	9.3	YES
8/3/25	1.35	248	336	11.9	6.9	17	8.2	YES
8/4/25	1.37	242	332	11.8	7.1	18	8.5	YES
8/5/25	1.23	273	335	11.5	7.1	18	6.7	YES
8/6/25	1.18	268	317	11.6	7.0	18	7.0	YES
8/7/25	1.13	267	303	11.6	6.9	17	7.0	YES
8/8/25	1.01	265	268	11.0	6.9	17	7.2	YES
8/9/25	1.06	275	290	11.0	7.0	18	6.6	YES
8/10/25	1.04	220	229	11.7	6.9	17	9.8	YES
8/11/25	1.14	249	283	12.5	6.8	16	8.1	YES
8/12/25	1.15	270	311	12.7	6.8	15	6.9	YES
8/13/25	1.07	225	241	13.0	6.9	15	9.5	YES
8/14/25	1.05	282	295	13.2	6.9	15	6.2	YES
8/15/25	1.04	276	288	13.2	6.9	15	6.5	YES
8/16/25	1.02	292	299	13.1	6.8	15	5.6	YES
8/17/25	0.75	275	206	12.8	6.8	14	6.6	YES
8/18/25	0.75	269	201	12.7	6.8	15	7.0	YES
8/19/25	0.88	253	223	12.4	6.9	16	7.9	YES
8/20/25	0.97	248	242	12.1	6.9	16	8.2	YES
8/21/25	1.00	264	264	11.6	6.9	17	7.3	YES
8/22/25	0.99	262	258	12.0	6.9	16	7.4	YES
8/23/25	0.98	221	217	12.7	6.8	15	9.8	YES
8/24/25	1.12	252	284	13.0	6.8	14	7.9	YES
8/25/25	1.16	216	251	13.5	6.9	15	10.0	YES
8/26/25	1.05	262	276	13.8	7.0	15	7.4	YES
8/27/25	1.03	279	287	14.4	6.9	14	6.4	YES
8/28/25	1.02	270	276	14.1	6.9	14	6.9	YES
8/29/25	0.99	275	272	14.0	6.9	14	6.6	YES
8/30/25	1.05	227	239	13.5	6.9	15	9.4	YES
8/31/25	1.13	239	270	13.3	7.0	15	8.7	YES