

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas



TURBIDITY MONITORING REPORT
FORM

MT/YR _____ CT req'd

Sep-25 0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	38.9	39.0	-0.1	15, 15	0.058	
2	43.7	43.8	0.0	15, 15	0.200	
3	41.3	41.4	-0.1	15, 15	0.160	
4	31.1	31.2	-0.1	15, 15	0.080	
5	40.0	40.1	-0.1	15, 15	0.053	
6	43.4	43.4	0.0	15, 15	0.195	
7	43.9	44.0	0.0	15, 15	0.205	
8	40.3	40.4	-0.1	15, 15	0.058	
9	44.9	45.0	-0.1	15, 15	0.190	
10	34.8	34.7	0.0	15, 15	0.078	
11	37.8	37.7	0.1	15, 15	0.080	
12	40.9	40.9	0.0	15, 15	0.235	
13	39.1	39.1	0.0	15, 15	0.053	
14	43.8	43.6	0.2	15, 15	0.068	
15	41.4	41.4	0.1	15, 15	0.400	
16	43.0	43.1	-0.1	15, 15	0.058	
17	40.9	41.0	-0.1	15, 15	0.218	
18	37.6	37.6	0.0	15, 15	0.233	
19	37.8	37.7	0.1	15, 15	0.110	
20	39.7	39.6	0.1	15, 15	0.070	
21	43.8	43.8	0.1	15, 15	0.230	
22	40.5	40.5	0.0	15, 15	0.335	
23	40.2	40.3	-0.1	15, 15	0.060	
24	37.7	37.6	0.1	15, 15	0.235	
25	39.1	39.1	0.0	15, 15	0.095	
26	43.9	43.8	0.1	15, 15	0.045	
27	42.5	42.5	0.0	15, 15	0.203	
28	43.4	43.3	0.2	15, 15	0.043	
29	39.3	39.3	0.0	15, 15	0.058	
30	39.0	39.0	0.0	15, 15	0.205	
			0			
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

10/6/2025

CERT #

3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
Minikahda Water District PWS ID# 4193609
SURFACE WATER QUALITY DATA

Sep-25

DATE	INE RESID	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
9/1/25	1.03	239	246	13.1	7.0	15	8.7	YES
9/2/25	0.98	276	271	12.9	7.0	16	6.5	YES
9/3/25	0.96	262	252	13.4	6.8	14	7.4	YES
9/4/25	1.03	204	209	14.0	6.8	13	10.8	YES
9/5/25	1.04	280	292	14.0	6.9	14	6.3	YES
9/6/25	1.04	272	284	14.3	6.9	14	6.8	YES
9/7/25	1.03	272	280	13.9	6.9	14	6.8	YES
9/8/25	0.93	284	265	13.3	6.9	15	6.1	YES
9/9/25	0.94	300	282	13.4	7.0	15	5.1	YES
9/10/25	0.91	228	208	13.3	6.9	15	9.3	YES
9/11/25	0.96	292	280	13.2	6.9	15	5.6	YES
9/12/25	0.93	286	265	12.9	6.9	15	6.0	YES
9/13/25	0.91	263	240	12.4	7.0	16	7.3	YES
9/14/25	0.93	285	265	12.2	7.0	17	6.0	YES
9/15/25	0.79	280	221	11.5	7.0	17	6.3	YES
9/16/25	0.78	293	228	11.0	7.0	18	5.5	YES
9/17/25	0.79	284	223	11.5	6.9	17	6.1	YES
9/18/25	0.75	250	187	11.5	7.0	17	8.1	YES
9/19/25	1.24	277	344	11.6	6.8	17	6.5	YES
9/20/25	1.20	281	338	11.7	6.9	17	6.3	YES
9/21/25	1.21	285	344	11.7	6.9	17	6.0	YES
9/22/25	0.83	290	240	10.9	6.9	17	5.8	YES
9/23/25	0.84	285	240	10.7	7.0	18	6.0	YES
9/24/25	0.91	274	250	11.0	6.9	18	6.7	YES
9/25/25	1.01	288	292	11.0	6.9	17	5.8	YES
9/26/25	1.03	297	306	10.5	6.9	18	5.3	YES
9/27/25	1.05	279	294	10.0	7.0	19	6.4	YES
9/28/25	1.04	281	293	10.0	7.0	19	6.3	YES
9/29/25	1.04	284	294	10.5	7.0	19	6.1	YES
9/30/25	1.04	270	280	10.2	7.0	19	6.9	YES