

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas



TURBIDITY MONITORING REPORT
FORM

MT/YR _____ CT req'd

Oct-25 0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	43.05	43.05	0	15, 15	0.0475	
2	42.05	42.05	0	15, 15	0.2225	
3	41.925	41.98	-0.05	15, 15	0.17	
4	39.275	39.25	0.025	15, 15	0.0825	
5	36.625	36.58	0.05	15, 15	0.06	
6	37.325	37.38	-0.05	15, 15	0.336	
7	41.875	41.73	0.15	15, 15	0.34	
8	45.6	45.58	0.025	15, 15	0.06	
9	45.05	44.9	0.15	15, 15	0.2075	
10	41.65	41.6	0.05	15, 15	0.0575	
11	46.5	46.5	0	15, 15	0.06	
12	42.05	42	0.05	15, 15	0.31	
13	45.975	45.85	0.125	15, 15	0.7525	
14	33.725	33.65	0.075	15, 15	0.6825	
15	18.7	18.78	-0.075	15, 15	0.7175	
16	22.5	22.48	0.025	15, 15	0.303	
17	46.7	46.55	0.15	15, 15	0.325	
18	45.775	45.73	0.05	15, 15	0.59	
19	48.775	48.7	0.075	15, 15	0.3675	
20	42.25	42.18	0.075	15, 15	0.26	
21	47.725	47.78	-0.05	15, 15	0.4225	
22	45.875	45.75	0.125	15, 15	0.4825	
23	42.975	43	-0.025	15, 15	0.395	
24	49.35	49.33	0.025	15, 15	0.385	
25	48.225	48.18	0.05	15, 15	0.365	
26	51.475	51.28	0.2	15, 15	0.3225	
27	49.025	48.95	0.075	15, 15	0.32	
28	48.725	48.58	0.15	15, 15	0.3125	
29	46.175	45.88	0.3	15, 15	0.3125	
30	44.025	43.88	0.15	15, 15	0.315	
31	48.325		48.325	15, 15	0.3225	
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

11/2/2025

CERT #

3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
Minikahda Water District PWS ID# 4193609

SURFACE WATER QUALITY DATA

Oct-25

DATE	INE RESID	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
10/1/25	1.29	292	377	10.1	7.0	20	5.6	YES
10/2/25	1.39	289	401	9.6	7.0	20	5.8	YES
10/3/25	0.99	293	289	9.7	7.0	20	5.5	YES
10/4/25	0.91	277	252	10.0	7.0	19	6.5	YES
10/5/25	0.99	279	276	9.4	6.9	20	6.4	YES
10/6/25	1.23	284	349	8.6	7.0	22	6.1	YES
10/7/25	1.30	281	365	8.5	7.0	22	6.3	YES
10/8/25	1.15	302	347	8.5	7.0	21	5.0	YES
10/9/25	1.15	324	371	8.5	7.0	22	3.8	YES
10/10/25	0.84	325	272	8.5	7.1	21	3.7	YES
10/11/25	0.75	330	249	8.5	7.0	21	3.4	YES
10/12/25	0.75	315	238	7.8	7.0	22	4.3	YES
10/13/25	1.12	347	388	7.0	7.0	24	2.4	YES
10/14/25	1.06	348	369	6.5	6.9	24	2.3	YES
10/15/25	1.04	348	361	6.1	6.9	24	2.4	YES
10/16/25	0.74	353	261	6.0	7.0	24	2.1	YES
10/17/25	0.47	347	162	6.5	7.0	23	2.4	YES
10/18/25	0.38	330	124	6.1	7.0	24	3.4	YES
10/19/25	0.38	329	124	6.7	7.2	24	3.5	YES
10/20/25	0.62	322	200	7.0	7.1	23	3.9	YES
10/21/25	0.85	331	282	6.6	7.1	24	3.3	YES
10/22/25	0.90	342	308	7.0	7.1	24	2.7	YES
10/23/25	0.89	330	293	7.0	7.1	24	3.4	YES
10/24/25	0.90	357	322	7.1	7.1	24	1.8	YES
10/25/25	0.89	350	312	6.9	7.1	24	2.2	YES
10/26/25	0.87	339	295	6.3	7.1	25	2.9	YES
10/27/25	0.83	347	289	5.9	7.1	26	2.4	YES
10/28/25	0.81	341	276	5.8	7.1	26	2.8	YES
10/29/25	0.81	323	261	6.1	7.2	27	3.8	YES
10/30/25	0.81	326	264	6.1	7.2	26	3.6	YES
10/31/25	0.91	340	311	5.8	7.2	27	2.8	YES