

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas



TURBIDITY MONITORING REPORT
FORM

MT/YR

CT req'd

Nov-25

0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	45.725	45.55	0.175	15, 15	0.313	
2	38.725	38.68	0.05	15, 15	0.310	
3	14.65	14.65	0	15, 15	0.313	
4	46.975	46.85	0.125	15, 15	0.356	
5	48.575	48.48	0.1	15, 15	0.410	
6	43.2	43.03	0.175	15, 15	0.353	
7	49.675	49.53	0.15	15, 15	0.658	
8	45.65	45.55	0.1	15, 15	0.148	
9	46.35	46.28	0.075	15, 15	0.413	
10	50.825	50.75	0.075	15, 15	0.320	
11	46.65	46.65	0	15, 15	0.095	
12	47.5	47.38	0.125	15, 15	0.100	
13	40.65	40.83	-0.175	15, 15	0.218	
14	46.725	46.65	0.075	15, 15	0.170	
15	49.325	49.33	0	15, 15	0.110	
16	43.975	44.03	-0.05	15, 15	0.225	
17	49.425	49.28	0.15	15, 15	0.100	
18	52.325	52.2	0.125	15, 15	0.105	
19	50.85	50.7	0.15	15, 15	0.258	
20	51.875	51.75	0.125	15, 15	0.170	
21	39.425	39.55	-0.125	15, 15	0.083	
22	33.5	33.45	0.05	15, 15	0.118	
23	33.575	33.48	0.1	15, 15	0.150	
24	42.9	42.78	0.125	15, 15	0.213	
25	45.625	45.6	0.025	15, 15	0.208	
26	49.925	49.85	0.075	15, 15	0.278	
27	43.3	43.28	0.025	15, 15	0.165	
28	44.1	44.08	0.025	15, 15	0.253	
29	42.7	42.58	0.125	15, 15	0.248	
30	40.625	40.53	0.1	15, 15	0.090	
			0			
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

12/6/2025

CERT #

3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
Minikahda Water District PWS ID# 4193609

SURFACE WATER QUALITY DATA

Nov-25

DATE	INE RESID	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
11/1/25	1.24	328	406	6.5	7.2	27	3.5	YES
11/2/25	1.01	343	346	6.8	7.0	24	2.7	YES
11/3/25	0.49	343	167	6.6	6.9	22	2.6	YES
11/4/25	0.41	340	138	6.6	6.8	21	2.8	YES
11/5/25	0.65	358	233	6.7	6.9	22	1.8	YES
11/6/25	0.65	307	199	6.5	6.9	23	4.8	YES
11/7/25	0.55	356	196	6.6	7.1	24	1.9	YES
11/8/25	0.95	336	319	6.4	7.0	24	3.0	YES
11/9/25	0.82	325	265	6.3	7.0	24	3.7	YES
11/10/25	1.04	345	357	6.3	7.1	25	2.5	YES
11/11/25	1.06	308	326	6.7	7.1	25	4.7	YES
11/12/25	1.18	302	355	7.1	7.0	24	5.0	YES
11/13/25	1.15	280	324	7.5	6.9	23	6.3	YES
11/14/25	1.27	326	413	7.8	6.9	22	3.6	YES
11/15/25	1.31	323	421	7.8	6.9	23	3.8	YES
11/16/25	1.32	305	403	7.7	7.0	23	4.9	YES
11/17/25	0.97	346	337	7.2	7.0	23	2.5	YES
11/18/25	0.82	357	291	6.1	6.9	24	1.8	YES
11/19/25	0.80	355	285	5.3	7.0	26	2.0	YES
11/20/25	0.82	340	280	5.0	7.1	27	2.8	YES
11/21/25	0.89	348	310	4.4	7.1	29	2.4	YES
11/22/25	1.04	327	340	4.3	7.2	30	3.6	YES
11/23/25	1.39	330	460	4.7	7.3	32	3.4	YES
11/24/25	1.07	311	332	5.2	7.2	29	4.5	YES
11/25/25	0.85	299	254	4.7	7.1	28	5.2	YES
11/26/25	0.83	282	235	4.7	7.1	28	6.2	YES
11/27/25	0.76	297	226	5.4	7.0	26	5.3	YES
11/28/25	0.94	299	282	5.9	7.0	25	5.2	YES
11/29/25	1.12	306	343	5.0	7.0	27	4.8	YES
11/30/25	1.17	282	330	4.1	7.1	30	6.2	YES