

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas



TURBIDITY MONITORING REPORT
FORM

MT/YR Dec-25 CT req'd 0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	53.8	53.7	0.1	15, 15	0.08	
2	48.7	48.6	0.1	15, 15	0.25	
3	52.2	52.2	-0.1	15, 15	0.13	
4	48.5	48.3	0.2	15, 15	0.85	
5	52.1	51.8	0.3	15, 15	0.84	
6	44.6	44.5	0.0	15, 15	0.90	
7	47.6	47.5	0.1	15, 15	0.88	
8	50.7	50.6	0.2	15, 15	0.92	
9	45.1	45.1	0.0	15, 15	0.64	
10	50.5	50.4	0.1	15, 15	0.46	
11	53.2	53.1	0.1	15, 15	0.73	
12	46.7	46.6	0.1	15, 15	0.25	
13	42.0	40.0	2.0	15, 15	0.51	
14	40.3	40.3	0.0	15, 15	0.08	
15	47.0	46.8	0.2	15, 15	0.30	
16	43.2	43.1	0.0	15, 15	0.23	
17	55.2	55.1	0.1	15, 15	0.31	
18	55.6	55.5	0.1	15, 15	0.17	
19	38.2	38.0	0.1	15, 15	0.15	
20	45.8	45.9	-0.1	15, 15	0.54	
21	37.4	37.4	0.0	15, 15	0.92	
22	41.2	38.6	2.6	15, 15	0.92	
23	41.9	41.8	0.1	15, 15	0.26	
24	48.5	48.3	0.2	15, 15	0.12	
25	43.7	43.6	0.1	15, 15	0.43	
26	42.8	42.7	0.0	15, 15	0.26	
27	42.0	42.0	0.0	15, 15	0.10	
28	43.8	43.8	0.0	15, 15	0.27	
29	44.1	44.0	0.1	15, 15	0.08	
30	44.5	44.3	0.2	15, 15	0.08	
31	49.7	49.7	0.0	15, 15	0.34	
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

1/5/2026

CERT #

3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Dec-25

DATE	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
12/1/25	1.23	303	373	3.8	7.2	32	5.0	YES
12/2/25	1.11	317	351	3.7	7.2	32	4.2	YES
12/3/25	1.12	323	360	3.6	7.2	32	3.8	YES
12/4/25	1.32	327	431	3.7	7.2	33	3.6	YES
12/5/25	1.67	315	526	4.2	7.4	35	4.3	YES
12/6/25	1.70	305	516	5.3	7.4	33	4.9	YES
12/7/25	2.06	252	520	5.6	7.3	33	7.9	YES
12/8/25	2.06	330	678	6.1	7.4	32	3.4	YES
12/9/25	2.03	317	644	6.5	7.4	31	4.2	YES
12/10/25	1.94	353	684	6.6	7.3	31	2.1	YES
12/11/25	1.77	347	613	7.2	7.3	28	2.4	YES
12/12/25	1.63	330	536	6.9	7.2	27	3.4	YES
12/13/25	1.70	329	558	6.1	7.3	30	3.5	YES
12/14/25	1.87	322	602	5.8	7.4	33	3.9	YES
12/15/25	1.73	331	573	6.2	7.4	31	3.3	YES
12/16/25	1.76	342	600	7.0	7.3	28	2.7	YES
12/17/25	1.58	330	521	6.2	7.3	30	3.4	YES
12/18/25	1.35	357	483	5.6	7.0	27	1.8	YES
12/19/25	1.46	350	512	5.1	7.2	30	2.2	YES
12/20/25	1.50	315	472	5.2	7.4	32	4.3	YES
12/21/25	2.02	280	565	4.6	7.0	31	6.3	YES
12/22/25	2.10	293	617	4.7	7.2	34	5.5	YES
12/23/25	1.98	302	598	4.7	7.2	33	5.0	YES
12/24/25	2.08	320	666	4.4	7.3	35	4.0	YES
12/25/25	2.08	317	659	4.3	7.3	35	4.2	YES
12/26/25	2.04	281	573	4.3	7.3	36	6.3	YES
12/27/25	1.94	302	587	3.8	7.3	36	5.0	YES
12/28/25	1.84	324	597	3.1	7.3	38	3.8	YES
12/29/25	1.77	325	575	2.7	7.3	38	3.7	YES
12/30/25	1.71	330	563	2.3	7.3	39	3.4	YES
12/31/25	1.64	315	516	2.3	7.2	38	4.3	YES