

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Jan-26

DAY	PSI	PSI	PSID	when to change	Daily Turbidity		HIGHEST READING
					NTU		NTU
1	41	41	0	15, 15	0.075		
2	37	37	0	15, 15	0.245		
3	37	37	0	15, 15	0.1275		
4	31	31	0	15, 15	0.845		
5	39	39	0	15, 15	0.84		
6	50	50	0	15, 15	0.9025		
7	47	47	0	15, 15	0.95		
8	42	42	0	15, 15	0.853		
9	46	46	0	15, 15	0.1865		
10	47	47	0	15, 15	0.769		
11	47	47	0	15, 15	0.733333		
12	50	50	0	15, 15	0.2475		
13	50	50	0	15, 15	0.508333		
14	45	45	0	15, 15	0.0775		
15	43	43	0	15, 15	0.295		
16	48	48	0	15, 15	0.225		
17	44	44	0	15, 15	0.305		
18	44	44	0	15, 15	0.1675		
19	43	43	0	15, 15	0.45		
20	52	52	0	15, 15	0.52		
21	51	51	0	15, 15	0.864		
22	50	50	0	15, 15	0.9612		
23	48	48	0	15, 15	0.2575		
24	47	47	0	15, 15	0.1225		
25	45	45	0	15, 15	0.43		
26	51	51	0	15, 15	0.255		
27	48	48	0	15, 15	0.095		
28	48	48	0	15, 15	0.2675		
29	47	47	0	15, 15	0.0825		
30	45	45	0	15, 15	0.075		
31	44	44	0	15, 15	0.335		

Daily Turbidity ngs < 1 ntu	yes	CL ₂ RESID AT Entry Point	yes
Turbidity Readings 5 NTU	yes	CT's Met Everyday?	yes

310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 2/4/2026 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Jan-26

DATE	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
1/1/26	1.63	328	536	1.2	7.2	81	3.5	YES
1/2/26	1.65	330	543	1.1	7.3	85	3.4	YES
1/3/26	1.59	339	537	1.1	7.3	84	2.9	YES
1/4/26	1.55	278	431	1.3	7.3	81	6.4	YES
1/5/26	1.42	328	466	1.7	7.2	76	3.5	YES
1/6/26	1.37	323	443	1.7	7.2	75	3.8	YES
1/7/26	1.29	311	402	2.1	7.2	72	4.5	YES
1/8/26	1.24	320	395	2.1	7.1	71	4.0	YES
1/9/26	1.24	313	386	2.0	7.1	71	4.4	YES
1/10/26	1.25	344	430	1.9	7.1	71	2.6	YES
1/11/26	1.29	340	438	1.8	7.2	74	2.8	YES
1/12/26	1.33	308	408	1.6	7.3	78	4.7	YES
1/13/26	1.28	328	420	1.7	7.2	74	3.5	YES
1/14/26	1.22	335	409	1.9	7.1	71	3.1	YES
1/15/26	1.16	310	359	1.7	7.1	70	4.6	YES
1/16/26	1.16	282	326	1.8	7.1	70	6.2	YES
1/17/26	1.17	309	362	1.6	7.1	71	4.6	YES
1/18/26	1.23	297	365	1.4	7.2	76	5.3	YES
1/19/26	1.21	330	401	1.4	7.1	74	3.4	YES
1/20/26	1.21	325	394	1.3	7.1	73	3.7	YES
1/21/26	0.94	323	304	2.0	7.0	65	3.8	YES
1/22/26	0.66	321	212	2.1	6.9	60	3.9	YES
1/23/26	0.61	321	195	2.0	6.8	59	3.9	YES
1/24/26	0.57	330	187	2.1	6.8	58	3.4	YES
1/25/26	0.57	313	177	2.1	6.8	58	4.4	YES
1/26/26	0.57	335	190	2.0	6.8	58	3.1	YES
1/27/26	0.84	351	295	1.9	7.0	65	2.2	YES
1/28/26	1.23	339	416	1.8	7.2	72	2.9	YES
1/29/26	1.51	357	538	1.8	7.3	79	1.8	YES
1/30/26	1.62	337	546	1.7	7.4	84	3.0	YES
1/31/26	1.67	330	551	1.6	7.5	87	3.4	YES

95% of l
 Readi
 All Daily Tt
 <
 phone 503-