

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Feb-26

0.5

DAY	PSI	PSI	PSID	when to	Daily Turbidity		
					NTU		
1	40.0	40.0	0.1	15, 15	0.16		
2	47.2	47.1	0.0	15, 15	0.0825		
3	51.2	51.0	0.2	15, 15	0.0875		
4	50.4	50.4	0.0	15, 15	0.1725		
5	52.5	52.4	0.1	15, 15	0.1975		
6	52.9	52.7	0.2	15, 15	0.06		
7	47.9	47.8	0.1	15, 15	0.1275		
8	51.6	51.3	0.3	15, 15	0.0525		
9	51.4	51.3	0.1	15, 15	0.175		
10	46.9	46.8	0.1	15, 15	0.185		
11	47.1	47.1	0.1	15, 15	0.055		
12	45.7	45.6	0.2	15, 15	0.0475		
13	51.4	51.3	0.1	15, 15	0.125		
14	45.6	45.5	0.1	15, 15	0.07		
15	44.2	44.1	0.1	15, 15	0.14		
16	41.2	41.3	-0.1	15, 15	0.215		
17	50.8	50.6	0.1	15, 15	0.055		
18	46.0	45.8	0.2	15, 15	0.0525		
19	49.7	49.6	0.1	15, 15	0.1475		
20	31.9	31.8	0.1	15, 15	0.18		
21	43.5	43.5	0.0	15, 15	0.0575		
22	50.2	50.1	0.1	15, 15	0.1375		
23	51.6	51.3	0.3	15, 15	0.0425		
24	49.4	49.2	0.2	15, 15	0.065		
25	50.1	49.9	0.3	15, 15	0.2325		
26	47.4	47.4	0.0	15, 15	0.1325		
27	48.1	48	0.1	15, 15	0.09		
28	46.5	46.4	0.1	15, 15	0.071		
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point	yes		
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?	yes		

310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 3/3/2026 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Feb-26

DATE	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
	PPM	minutes	C x T	C°		Equation	GPM	YES/NO
2/1/26	1.77	303	536	3.27	7.59	41	5.0	YES
2/2/26	1.69	335	567	3.51	7.59	40	3.1	YES
2/3/26	1.57	344	540	3.51	7.53	39	2.6	YES
2/4/26	1.48	353	522	4	7.47	36	2.1	YES
2/5/26	1.43	365	523	4.06	7.45	35	1.3	YES
2/6/26	1.41	358	502	3.88	7.45	36	1.8	YES
2/7/26	1.36	330	448	3.82	7.4025	35	3.4	YES
2/8/26	1.33	340	453	4.2325	7.36	33	2.8	YES
2/9/26	1.24	356	441	3.97	7.3	33	1.9	YES
2/10/26	1.17	327	382	3.36	7.275	34	3.6	YES
2/11/26	1.17	302	354	3.065	7.31	35	5.0	YES
2/12/26	1.17	333	389	2.87	7.365	36	3.3	YES
2/13/26	1.15	348	401	2.96	7.365	36	2.3	YES
2/14/26	1.09	327	355	3.51	7.25	33	3.6	YES
2/15/26	1.14	320	364	3.76	7.21	32	4.0	YES
2/16/26	1.25	320	399	3.51	7.23	33	4.0	YES
2/17/26	1.24	345	426	2.69	7.285	36	2.5	YES
2/18/26	1.12	320	359	2.17	7.3075	37	4.0	YES
2/19/26	1.08	331	357	2.11	7.3075	37	3.3	YES
2/20/26	1.05	270	284	2.17	7.23	36	6.9	YES
2/21/26	1.20	322	387	2.54	7.165	35	3.9	YES
2/22/26	1.15	331	382	2.54	7.16	34	3.3	YES
2/23/26	1.08	359	387	2.78	7.16	33	1.7	YES
2/24/26	1.05	335	352	3.02	7.15	33	3.1	YES
2/25/26	1.06	344	364	3.05	7.155	33	2.6	YES
2/26/26	0.72	335	241	2.54	7.01	31	3.1	YES
2/27/26	0.53	335	177	2.17	6.88	29	3.1	YES
2/28/26	0.54	344	186	4.25	7.14	28	2.6	YES