

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Feb-21

CT MET	DAY	PSI	PSI	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.27		
YES	2	55	54	1	15, 15	0.57		
YES	3	55	54	1	15, 15	0.28		
YES	4	54	53	1	15, 15	0.31		
YES	5	56	55	1	15, 15	0.39		
YES	6	55	54	1	15, 15	0.36		
YES	7	54	53	1	15, 15	0.32		
YES	8	55	54	1	15, 15	0.52		
YES	9	56	55	1	15, 15	0.33		
YES	10	52	51	1	15, 15	0.41		
YES	11	56	55	1	15, 15	0.32		
YES	12	50	49	1	15, 15	0.41		
YES	13	55	54	1	15, 15	0.28		
YES	14	54	53	1	15, 15	0.64		
YES	15	55	54	1	15, 15	0.41		
YES	16	57	56	1	15, 15	0.53		
YES	17	45	44	1	15, 15	0.31		
YES	18	46	45	1	15, 15	0.44		
YES	19	42	41	1	15, 15	0.4		
YES	20	44	43	1	15, 15	0.37		
YES	21	46	45	1	15, 15	0.34		
YES	22	45	44	1	15, 15	0.33		
YES	23	50	49	1	15, 15	0.39		
YES	24	54	53	1	15, 15	0.34		
YES	25	55	54	1	15, 15	0.29		
YES	26	56	55	1	15, 15	0.27		
YES	27	54	53	1	15, 15	0.28		
YES	28	54	53	1	15, 15	0.28		
95% of Daily Turbidity Readings < 1 ntu Yes							CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 3/3/2021 CERT # 3675

