

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 Minikahda Water District PWS ID# 4193609  
 TURBIDITY MONITORING REPORT FORM

MT/YR                      Apr-21

CT MET	DAY	PSI	PSID	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.39		
YES	2	53	52	1	15, 15	0.47		
YES	3	54	53	1	15, 15	0.38		
YES	4	54	53	1	15, 15	0.28		
YES	5	50	49	1	15, 15	0.65		
YES	6	55	54	1	15, 15	0.45		
YES	7	52	51	1	15, 15	0.24		
YES	8	56	55	1	15, 15	0.38		
YES	9	54	53	1	15, 15	0.3		
YES	10	52	51	1	15, 15	0.54		
YES	11	58	57	1	15, 15	0.29		
YES	12	54	53	1	15, 15	0.38		
YES	13	51	50	1	15, 15	0.45		
YES	14	50	49	1	15, 15	0.4		
YES	15	54	53	1	15, 15	0.39		
YES	16	52	51	1	15, 15	0.37		
YES	17	51	50	1	15, 15	0.37		
YES	18	50	49	1	15, 15	0.36		
YES	19	56	55	1	15, 15	0.31		
YES	20	57	56	1	15, 15	0.58		
YES	21	52	51	1	15, 15	0.44		
YES	22	50	49	1	15, 15	0.41		
YES	23	53	52	1	15, 15	0.34		
YES	24	55	54	1	15, 15	0.31		
YES	25	51	50	1	15, 15	0.39		
YES	26	51	50	1	15, 15	0.32		
YES	27	50	49	1	15, 15	0.38		
YES	28	55	54	1	15, 15	0.31		
YES	29	56	55	1	15, 15	0.39		
YES	30	57	56	1	15, 15	0.28		
							CL <sub>2</sub> RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob  
 PRINT NAME David Jacob

DATE 5/4/2021 CERT # 3675

