

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Jun-22

CT MET	DAY	PSI	PSI	PSID	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	51	50	1	15, 15	0.34		
YES	2	52	51	1	15, 15	0.28		
YES	3	51	50	1	15, 15	0.55		
YES	4	50	49	1	15, 15	0.43		
YES	5	51	50	1	15, 15	0.55		
YES	6	52	51	1	15, 15	0.29		
YES	7	53	52	1	15, 15	0.41		
YES	8	50	49	1	15, 15	0.27		
YES	9	50	49	1	15, 15	0.43		
YES	10	53	52	1	15, 15	0.44		
YES	11	53	52	1	15, 15	0.39		
YES	12	53	52	1	15, 15	0.34		
YES	13	52	51	1	15, 15	0.40		
YES	14	50	49	1	15, 15	0.52		
YES	15	48	47	1	15, 15	0.63		
YES	16	48	47	1	15, 15	0.55		
YES	17	50	49	1	15, 15	0.68		
YES	18	49	48	1	15, 15	0.37		
YES	19	50	49	1	15, 15	0.48		
YES	20	50	49	1	15, 15	0.44		
YES	21	52	51	1	15, 15	0.29		
YES	22	53	52	1	15, 15	0.44		
YES	23	55	54	1	15, 15	0.37		
YES	24	53	52	1	15, 15	0.27		
YES	25	52	51	1	15, 15	0.27		
YES	26	53	52	1	15, 15	0.33		
YES	27	55	54	1	15, 15	0.32		
YES	28	50	49	1	15, 15	0.33		
YES	29	49	48	1	15, 15	0.27		
YES	30	56	55	1	15, 15	0.31		
							CL ₂ RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L NO	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? NO	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 7/15/2022 rev 1 CERT # 3675

