

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Jul-22

CT MET	DAY	psid pre	psid post		PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.43		
YES	2	49	48	1	15, 15	0.53		
YES	3	52	51	1	15, 15	0.37		
YES	4	51	50	1	15, 15	0.55		
YES	5	55	54	1	15, 15	0.43		
YES	6	53	52	1	15, 15	0.44		
YES	7	53	52	1	15, 15	0.42		
YES	8	53	52	1	15, 15	0.28		
YES	9	50	49	1	15, 15	0.29		
YES	10	45	44	1	15, 15	0.46		
YES	11	45	44	1	15, 15	0.32		
YES	12	52	51	1	15, 15	0.27		
YES	13	53	52	1	15, 15	0.29		
YES	14	57	56	1	15, 15	0.27		
YES	15	52	51	1	15, 15	0.37		
YES	16	50	49	1	15, 15	0.3		
YES	17	53	52	1	15, 15	0.28		
YES	18	53	52	1	15, 15	0.41		
YES	19	55	54	1	15, 15	0.28		
YES	20	56	55	1	15, 15	0.39		
YES	21	58	57	1	15, 15	0.25		
YES	22	56	55	1	15, 15	0.3		
YES	23	55	54	1	15, 15	0.32		
YES	24	56	55	1	15, 15	0.31		
YES	25	55	54	1	15, 15	0.26		
YES	26	58	57	1	15, 15	0.29		
YES	27	56	55	1	15, 15	0.36		
YES	28	55	54	1	15, 15	0.32		
YES	29	54	53	1	15, 15	0.28		
YES	30	55	54	1	15, 15	0.26		
YES	31	56	55	1	15, 15	0.35		
95% of Daily Turbidity Readings < 1 ntu Yes							CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 8/4/2022 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Jul-22

DATE	TIME	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW
		PPM	minutes	C x T	C°		Equation	GPM
7/1/22	13:25	1.30	191	248	13	7.4	37	4.1
7/2/22	15:30	1.30	100	130	13	7.4	37	7.8
7/3/22	16;	1.40	119	166	13	7.4	38	6.6
7/4/22	17:20	1.20	170	204	13	7.4	37	4.6
7/5/22	18;	1.30	144	187	11	7.4	43	5.4
7/6/22	17:30	1.30	239	311	11	7.4	43	3.3
7/7/22	13;	1.30	123	160	11	7.4	43	6.3
7/8/22	14;	1.30	237	308	11	7.4	43	3.3
7/9/22	13;	1.30	122	159	12	7.4	40	6.4
7/10/22	17:10	1.30	150	195	12	7.4	40	5.2
7/11/22	12:45	1.30	53	69	13	7.4	37	14.7
7/12/22	11:30	1.30	108	141	13	7.4	37	7.2
7/13/22	18:25	1.30	169	220	14	7.4	35	4.6
7/14/22	18;	1.30	117	153	13	7.5	39	6.6
7/15/22	15:00	1.30	81	105	13	7.4	37	9.6
7/16/22	18;	1.30	112	145	13	7.4	37	7.0
7/17/22	15:45	1.30	116	151	13	7.4	37	6.7
7/18/22	13:00	1.30	113	147	13	7.5	39	6.9
7/19/22	13:45	1.30	126	164	13	7.4	37	6.2
7/20/22	17:15	1.25	141	177	14	7.4	35	5.5
7/21/22	11:20	1.30	116	151	14	7.3	34	6.7
7/22/22	12:45	1.30	136	177	14	7.4	35	5.7
7/23/22	10:10	1.30	96	125	14	7.4	35	8.1
7/24/22	20:30	1.30	132	171	14	7.4	35	5.9
7/25/22	12:20	1.30	125	163	15	7.4	33	6.2
7/26/22	16:45	1.30	113	147	15	7.5	34	6.9
7/27/22	17:00	1.30	117	152	15	7.4	33	6.7
7/28/22	16:16	1.30	123	160	15	7.4	33	6.3
7/29/22	16:16	1.30	95	124	16	7.4	31	8.2
7/30/22	14:45	1.30	106	138	16	7.4	31	7.4
7/31/22	12:00	1.20	92	110	15	7.4	32	8.5

[]