

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Aug-22

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.4		
YES	2	57	56	1	15, 15	0.25		
YES	3	56	55	1	15, 15	0.25		
YES	4	56	55	1	15, 15	0.25		
YES	5	54	53	1	15, 15	0.29		
YES	6	56	55	1	15, 15	0.32		
YES	7	54	53	1	15, 15	0.36		
YES	8	55	54	1	15, 15	0.26		
YES	9	56	55	1	15, 15	0.34		
YES	10	55	54	1	15, 15	0.28		
YES	11	56	55	1	15, 15	0.3		
YES	12	55	54	1	15, 15	0.35		
YES	13	54	53	1	15, 15	0.39		
YES	14	56	55	1	15, 15	0.29		
YES	15	54	53	1	15, 15	0.28		
YES	16	56	55	1	15, 15	0.36		
YES	17	55	54	1	15, 15	0.41		
YES	18	51	50	1	15, 15	0.38		
YES	19	50	49	1	15, 15	0.26		
YES	20	52	51	1	15, 15	0.31		
YES	21	51	50	1	15, 15	0.33		
YES	22	50	49	1	15, 15	0.27		
YES	23	56	55	1	15, 15	0.33		
YES	24	56	55	1	15, 15	0.31		
YES	25	56	55	1	15, 15	0.33		
YES	26	55	54	1	15, 15	0.28		
YES	27	56	55	1	15, 15	0.33		
YES	28	55	54	1	15, 15	0.32		
YES	29	56	55	1	15, 15	0.32		
YES	30	53	52	1	15, 15	0.33		
YES	31	56	55	1	15, 15	0.27		
							CL ₂ RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 9/6/2022 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Aug-22

DATE	TIME	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW
		PPM	minutes	C x T	C°		Equation	GPM
8/1/22	15:00	1.40	138	193	15	7.4	33	5.7
8/2/22	19:00	1.30	114	149	15	7.4	33	6.8
8/3/22	19:30	1.30	120	157	15	7.5	34	6.5
8/4/22	15:45	1.30	115	149	15	7.4	33	6.8
8/5/22	18:45	1.30	109	141	14	7.4	35	7.2
8/6/22	18:00	1.30	135	176	15	7.4	33	5.8
8/7/22	18:30	1.30	129	168	15	7.4	33	6.0
8/8/22	15:30	1.20	96	115	15	7.3	31	8.2
8/9/22	10:00	1.30	115	150	14	7.4	35	6.8
8/10/22	13:45	1.30	129	167	14	7.4	35	6.1
8/11/22	17:00	1.30	120	156	15	7.5	34	6.5
8/12/22	17:15	1.20	109	131	15	7.5	34	7.2
8/13/22	15:30	1.30	128	166	15	7.4	33	6.1
8/14/22	18:35	1.30	124	162	15	7.4	33	6.3
8/15/22	13:45	1.30	120	157	15	7.3	32	6.5
8/16/22	10:50	1.30	75	97	16	7.4	31	10.4
8/17/22	8:40	1.30	118	153	16	7.4	31	6.6
8/18/22	14:00	1.30	104	136	15	7.4	33	7.5
8/19/22	18:00	1.20	75	90	16	7.5	31	10.4
8/20/22	17:00	1.30	104	135	16	7.5	32	7.5
8/21/22	18:00	1.30	75	97	16	7.4	31	10.4
8/22/22	16:00	1.30	75	98	16	7.4	31	10.4
8/23/22	10:30	1.30	148	193	16	7.5	32	5.3
8/24/22	8:45	1.30	118	153	16	7.5	32	6.6
8/25/22	11:30	1.30	94	123	16	7.4	31	8.3
8/26/22	11:15	1.30	130	169	15	7.4	33	6.0
8/27/22	18:30	1.20	136	164	14	7.4	35	5.7
8/28/22	14:00	1.30	146	190	15	7.4	33	5.3
8/29/22	12:45	1.30	137	178	15	7.4	33	5.7
8/30/22	13:45	1.30	115	149	15	7.4	33	6.8
8/31/22	16:00	1.30	170	220	15	7.5	34	4.6