

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Nov-22

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	55	54	1	15, 15	0.35		
YES	2	54	53	1	15, 15	0.33		
YES	3	50	49	1	15, 15	0.34		
YES	4	55	54	1	15, 15	0.31		
YES	5	54	53	1	15, 15	0.45		
YES	6	53	52	1	15, 15	0.52		
YES	7	53	52	1	15, 15	0.31		
YES	8	55	54	1	15, 15	0.28		
YES	9	51	50	1	15, 15	0.35		
YES	10	49	48	1	15, 15	0.34		
YES	11	49	48	1	15, 15	0.44		
YES	12	52	51	1	15, 15	0.59		
YES	13	52	51	1	15, 15	0.29		
YES	14	51	50	1	15, 15	0.28		
YES	15	52	51	1	15, 15	0.35		
YES	16	55	54	1	15, 15	0.34		
YES	17	49	48	1	15, 15	0.34		
YES	18	49	48	1	15, 15	0.45		
YES	19	55	54	1	15, 15	0.23		
YES	20	54	53	1	15, 15	0.30		
YES	21	50	49	1	15, 15	0.40		
YES	22	50	49	1	15, 15	0.51		
YES	23	55	54	1	15, 15	0.26		
YES	24	52	51	1	15, 15	0.48		
YES	25	51	50	1	15, 15	0.48		
YES	26	51	50	1	15, 15	0.51		
YES	27	51	50	1	15, 15	0.32		
YES	28	53	52	1	15, 15	0.36		
YES	29	53	52	1	15, 15	0.36		
YES	55	52	51	1	15, 15	0.40		
							CL ₂ RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob

PRINT NAME David Jacob

DATE 12/3/2022 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Nov-22

DATE	TIME	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW
		PPM	minutes	C x T	C°		Equation	GPM
11/1/22	10:00	1.30	215	279	7	7.4	56	3.6
11/2/22	12:00	1.30	318	414	7	7.4	56	2.5
11/3/22	16:45	1.30	223	290	7	7.4	56	3.5
11/4/22	13:00	1.30	260	338	7	7.5	58	3.0
11/5/22	13:30	1.20	199	239	7	7.5	57	3.9
11/6/22	13:00	1.30	220	286	7	7.4	56	3.5
11/7/22	14:00	1.30	223	290	7	7.5	58	3.5
11/8/22	15:45	1.20	250	300	7	7.5	57	3.1
11/9/22	16:00	1.20	219	263	7	7.4	55	3.6
11/10/22	0:00	1.30	288	374	6	7.5	62	2.7
11/11/22	15:50	1.30	214	279	6	7.4	60	3.6
11/12/22	13:00	1.30	195	253	6	7.4	60	4.0
11/13/22	16:00	1.20	163	195	7	7.4	55	4.8
11/14/22	15:00	1.20	247	297	7	7.4	55	3.2
11/15/22	17:30	1.30	191	248	7	7.5	58	4.1
11/16/22	13:14	1.30	224	291	7	7.4	56	3.5
11/17/22	17:00	1.20	128	153	7	7.4	55	6.1
11/18/22	13:00	1.20	243	292	7	7.4	55	3.2
11/19/22	16:15	1.20	169	203	7	7.4	55	4.6
11/20/22	15:00	1.30	191	248	7	7.4	56	4.1
11/21/22	14:00	1.30	256	333	6	7.5	62	3.0
11/22/22	14:00	1.20	194	233	6	7.5	62	4.0
11/23/22	13:30	1.20	134	161	6	7.4	59	5.8
11/24/22	15:40	1.30	260	338	5	7.4	64	3.0
11/25/22	16:30	1.20	232	278	5	7.5	66	3.4
11/26/22	15:10	1.20	101	122	5	7.5	66	7.7
11/27/22	10:00	1.30	269	349	4	7.5	71	2.9
11/28/22	7:40	1.20	292	350	4	7.4	68	2.7
11/29/22	16:30	1.30	257	334	5	7.4	64	3.0
11/30/22	16:30	1.30	242	315	4	7.4	69	3.2
							-	