

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 TURBIDITY MONITORING REPORT FORM

MT/YR Dec-22

CT MET	DAY	supply press	psid pre	psid post	PSI when to	Daily Turbidity		HIGHEST READING
YES/NO						NTU		NTU
YES	1	54	53	1	15, 15	0.32		
YES	2	49	48	1	15, 15	0.35		
YES	3	51	50	1	15, 15	0.29		
YES	4	52	51	1	15, 15	0.34		
YES	5	51	50	1	15, 15	0.41		
YES	6	50	49	1	15, 15	0.32		
YES	7	50	49	1	15, 15	0.36		
YES	8	52	51	1	15, 15	0.31		
YES	9	53	52	1	15, 15	0.30		
YES	10	51	50	1	15, 15	0.40		
YES	11	50	49	1	15, 15	0.35		
YES	12	49	48	1	15, 15	0.36		
YES	13	49	48	1	15, 15	0.38		
YES	14	48	47	1	15, 15	0.35		
YES	15	52	51	1	15, 15	0.34		
YES	16	52	51	1	15, 15	0.33		
YES	17	51	50	1	15, 15	0.23		
YES	18	51	50	1	15, 15	0.28		
YES	19	48	47	1	15, 15	0.23		
YES	20	49	48	1	15, 15	0.34		
YES	21	47	46	1	15, 15	0.36		
YES	22	48	47	1	15, 15	0.31		
YES	23	35	34	1	15, 15	0.31		
YES	24	34	33	1	15, 15	0.33		
YES	25	34	33	1	15, 15	0.65		
YES	26	33	32	1	15, 15	0.58		
YES	27	35	34	1	15, 15	0.56		
YES	28	36	35	1	15, 15	0.42		
YES	29	37	36	1	15, 15	0.35		
YES	30	38	37	1	15, 15	0.36		
YES	31	39	38	1	15, 15	0.42		
							CL ₂ RESID AT Entry Point	
95% of Daily Turbidity Readings < 1 ntu Yes							ALWAYS >0.2 MG/L Yes	
All Daily Turbidity Readings < 5 NTU Yes							CT's Met Everyday? Yes	

phone 503-310-9262

SIGNATURE: David Jacob
 PRINT NAME David Jacob
 DATE 1/8/2023 CERT # 3675

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 Minikahda Water District PWS ID# 4193609
 SURFACE WATER QUALITY DATA

Dec-22

DATE	TIME	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW
		PPM	minutes	C x T	C°		Equation	GPM
12/1/22	17:30	1.30	269	350	4	7.4	69	2.9
12/2/22	17:15	1.30	250	325	4	7.4	69	3.1
12/3/22	15:30	1.30	182	237	4	7.4	69	4.3
12/4/22	16:00	1.30	177	230	4	7.4	69	4.4
12/5/22	16:00	1.30	252	328	4	7.4	69	3.1
12/6/22	16:45	1.30	205	266	4	7.4	69	3.8
12/7/22	17:50	1.30	228	297	4	7.4	69	3.4
12/8/22	19:45	1.30	281	365	5	7.4	64	2.8
12/9/22	13:00	1.30	220	286	3	7.4	74	3.5
12/10/22	15:15	1.30	198	258	3	7.4	74	3.9
12/11/22	15:40	1.30	201	261	3	7.4	74	3.9
12/12/22	14:00	1.30	198	257	3	7.4	74	3.9
12/13/22	17:00	1.30	247	321	4	7.4	69	3.2
12/14/22	17:00	1.30	368	479	4	7.4	69	2.1
12/15/22	17:15	1.30	297	386	3	7.4	74	2.6
12/16/22	17:00	1.30	265	345	3	7.4	74	2.9
12/17/22	14:00	1.30	176	229	3	7.4	74	4.4
12/18/22	13:00	1.30	176	229	3	7.4	74	4.4
12/19/22	12:30	1.30	99	129	3	7.4	74	7.9
12/20/22	20:15	1.30	163	211	3	7.4	74	4.8
12/21/22	22:00	1.30	202	262	3	7.4	74	3.9
12/22/22	13:00	1.30	141	184	3	7.4	74	5.5
12/23/22	15:00	1.30	100	130	4	7.4	69	7.8
12/24/22	15:00	1.40	61	85	4	7.4	70	12.8
12/25/22	14:30	1.40	58	81	4	7.4	70	13.4
12/26/22	16:45	1.40	57	80	4	7.4	70	13.7
12/27/22	17:00	1.40	98	137	4	7.4	70	8.0
12/28/22	17:15	1.40	98	137	4	7.4	70	8.0
12/29/22	17:45	1.40	80	112	4	7.4	70	9.8
12/30/22	16:15	1.40	94	132	4	7.4	70	8.3
12/31/22	12:15	1.40	90	126	4	7.4	70	8.7