

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas



TURBIDITY MONITORING REPORT
FORM

MT/YR

CT req'd

Apr-24

0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	50.6	50.5	0.1	15, 15	0.05	
2	52.1	51.9	0.2	15, 15	0.09	
3	54.9	54.7	0.2	15, 15	0.05	
4	51.7	51.6	0.1	15, 15	0.1	
5	53.8	53.6	0.2	15, 15	0.11	
6	52.3	52.2	0.1	15, 15	0.04	
7	53.6	53.5	0.1	15, 15	0.04	
8	53	52.9	0.1	15, 15	0.09	
9	52.1	52	0.1	15, 15	0.07	
10	53.5	53.2	0.3	15, 15	0.05	
11	49.8	49.7	0.1	15, 15	0.09	
12	53.8	53.5	0.3	15, 15	0.06	
13	50.3	50.2	0.1	15, 15	0.05	
14	52.3	52.1	0.2	15, 15	0.12	
15	53.7	53.6	0.1	15, 15	0.05	
16	52.1	52	0.1	15, 15	0.05	
17	53.5	53.3	0.2	15, 15	0.14	
18	52.6	52.5	0.1	15, 15	0.06	
19	52.8	52.7	0.1	15, 15	0.13	
20	53.5	53.5	0	15, 15	0.17	
21	51.6	51.5	0.1	15, 15	0.09	
22	51.4	51.3	0.1	15, 15	0.09	
23	52.6	52.4	0.2	15, 15	0.2	
24	51.3	51.2	0.1	15, 15	0.17	
25	52.4	52.3	0.1	15, 15	0.09	
26	52.5	52.2	0.3	15, 15	0.21	
27	48.8	48.7	0.1	15, 15	0.65	
28	46.4	46.4	0	15, 15	0.13	
29	51.9	52	-0.1	15, 15	0.25	
30	51.3	51.3	0	15, 15	0.11	
			0			
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

5/2/2024

CERT #

3675

