

OHA - Drinking Water Program - Turbidity
Monitoring Report form County Clackamas

TURBIDITY MONITORING REPORT MT/YR CT req'd
FORM Jun-24 0.5

DAY	PSI	PSID	PSID	PSI when to change	Daily Turbidity	
					NTU	
1	40.4	40.4	0	15, 15	0.28	
2	43.6	43.6	0	15, 15	0.17	
3	43.6	43.5	0.1	15, 15	0.31	
4	41.8	41.6	0.2	15, 15	0.29	
5	37.7	37.8	-0.1	15, 15	0.18	
6	33.2	33.3	-0.1	15, 15	0.19	
7	34.9	34.9	0	15, 15	0.33	
8	33.6	33.5	0.1	15, 15	0.25	
9	36.8	36.8	0	15, 15	0.11	
10	36.4	36.4	0	15, 15	0.29	
11	39.4	39.3	0.1	15, 15	0.12	
12	34.8	34.8	0	15, 15	0.23	
13	33	33	0	15, 15	0.35	
14	26.8	27	-0.2	15, 15	0.14	
15	37.4	37.4	0	15, 15	0.1	
16	38	38	0	15, 15	0.26	
17	34.4	34.5	-0.1	15, 15	0.1	
18	32.3	32.3	0	15, 15	0.21	
19	23	23	0	15, 15	0.23	
20	30.5	30.5	0	15, 15	0.11	
21	37.3	37.3	0	15, 15	0.11	
22	27.5	27.5	0	15, 15	0.32	
23	32.1	32	0.1	15, 15	0.24	
24	30.8	30.8	0	15, 15	0.2	
25	35.1	35	0.1	15, 15	0.24	
26	39.4	39.4	0	15, 15	0.12	
27	42.3	42.2	0.1	15, 15	0.18	
28	34.9	34.9	0	15, 15	0.35	
29	35.4	35.4	0	15, 15	0.24	
30	49	49	0	15, 15	0.21	
			0			
95% of Daily Turbidity Readings < 1 ntu			yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L		yes
All Daily Turbidity Readings < 5 NTU			yes	CT's Met Everyday?		yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

6-Jul-24

CERT #

3675

