

## OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

## Cartridge or Bag Filtration

Month/Year: May-25

| System Name: Whistler's Bend |                   | ID#: 41 93944    |      | WTP ID: TP-                |                               |                                               |
|------------------------------|-------------------|------------------|------|----------------------------|-------------------------------|-----------------------------------------------|
| Day                          | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
| 1                            | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 2                            | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 3                            | 120.00            | 120.00           | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 4                            | 20.00             | 20.00            | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 5                            | 20.00             | 20.00            | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 6                            | 120.00            | 120.00           | 0.00 | 35.00                      | 0.04                          | 0.04                                          |
| 7                            | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 8                            | 120.00            | 120.00           | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 9                            | 120.00            | 120.00           | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 10                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 11                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 12                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 13                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 14                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 15                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 16                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 17                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 18                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 19                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.03                          | 0.03                                          |
| 20                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.02                          | 0.02                                          |
| 21                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.04                          | 0.04                                          |
| 22                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.04                          | 0.04                                          |
| 23                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.05                          | 0.05                                          |
| 24                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.05                          | 0.05                                          |
| 25                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.05                          | 0.05                                          |
| 26                           | 120.00            | 120.00           | 0.00 | 35.00                      | 0.07                          | 0.07                                          |
| 27                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.08                          | 0.08                                          |
| 28                           | 20.00             | 20.00            | 0.00 | 35.00                      | 0.05                          | 0.05                                          |
| 29                           | 40.00             | 40.00            | 0.00 | 35.00                      | 0.07                          | 0.07                                          |
| 30                           | 125.00            | 125.00           | 0.00 | 35.00                      | 0.08                          | 0.08                                          |
| 31                           | 125.00            | 125.00           | 0.00 | 35.00                      | 0.09                          | 0.09                                          |

|                                                                                                                                                                                                                                                        |  |                                                                                                                                                                                                                                                       |  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| <b>Cartridge &amp; Bag Filtration</b><br>95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No<br>All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No |  | <b>Monthly Summary (Answer Yes or No)</b><br>CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No<br>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No |  |
| <b>Notes:</b> PSI = pounds per square inch<br>PSID = pounds per square inch difference (before filter - after filter)<br>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.        |  | PRINTED NAME: Kelly Sharniff<br>SIGNATURE: <i>Kelly Sharniff</i><br>PHONE #: (541) 671-9891<br>DATE: 6-4-2025<br>CERT #:                                                                                                                              |  |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

PAGE 1 of 2  
 on well, Changed TO surface water  
 6-1-2025

## OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

|              |                 |         |       |             |        |                                         |   |
|--------------|-----------------|---------|-------|-------------|--------|-----------------------------------------|---|
| System Name: | Whistler's Bend | ID#: 41 | 93944 | Month/Year: | May-25 | Disinfection<br>Giardia Log<br>Inactiv: | 1 |
|--------------|-----------------|---------|-------|-------------|--------|-----------------------------------------|---|

| Date / Time | Minimum Cl <sub>2</sub><br>Residual at 1st<br>User ( C ) <sup>2</sup> | Contact Time<br>(T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>2</sup> | Peak<br>Hourly<br>Demand<br>Flow |
|-------------|-----------------------------------------------------------------------|---------------------|-----------|-------|------|-------------|----------------------|----------------------------------|
|             | [ppm or mg/L]                                                         | [minutes]           | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                            |
| 1           | 0.8                                                                   | 42                  | 33.6      | 11.6  | 6.80 | 31.8        | YES                  | 20                               |
| 2           | 0.8                                                                   | 42                  | 33.6      | 12.2  | 6.80 | 30.6        | YES                  | 30                               |
| 3           | 1                                                                     | 42                  | 42.0      | 11.4  | 6.90 | 34.1        | YES                  | 30                               |
| 4           | 1                                                                     | 42                  | 42.0      | 12.3  | 6.90 | 32.2        | YES                  | 20                               |
| 5           | 1                                                                     | 42                  | 42.0      | 12.8  | 7.00 | 31.6        | YES                  | 20                               |
| 6           | 1                                                                     | 42                  | 42.0      | 11.7  | 7.00 | 34.6        | YES                  | 20                               |
| 7           | 1.1                                                                   | 42                  | 46.2      | 11.8  | 6.90 | 33.6        | YES                  | 20                               |
| 8           | 1.1                                                                   | 42                  | 46.2      | 12.7  | 6.90 | 31.0        | YES                  | 20                               |
| 9           | 1                                                                     | 42                  | 42.0      | 12.4  | 7.00 | 33.1        | YES                  | 20                               |
| 10          | 1.1                                                                   | 42                  | 46.2      | 12.9  | 7.10 | 32.9        | YES                  | 30                               |
| 11          | 1.1                                                                   | 42                  | 46.2      | 12.4  | 7.00 | 33.4        | YES                  | 30                               |
| 12          | 1.1                                                                   | 42                  | 46.2      | 12.2  | 7.10 | 35.0        | YES                  | 20                               |
| 13          | 1.1                                                                   | 42                  | 46.2      | 11.8  | 7.10 | 36.0        | YES                  | 20                               |
| 14          | 1.1                                                                   | 42                  | 46.2      | 11.8  | 7.00 | 34.7        | YES                  | 20                               |
| 15          | 1.2                                                                   | 42                  | 50.4      | 12.1  | 6.80 | 32.2        | YES                  | 20                               |
| 16          | 1.2                                                                   | 42                  | 50.4      | 11.5  | 6.90 | 34.6        | YES                  | 30                               |
| 17          | 1.2                                                                   | 42                  | 50.4      | 11.3  | 6.90 | 35.1        | YES                  | 30                               |
| 18          | 1.2                                                                   | 42                  | 50.4      | 12.4  | 6.80 | 31.6        | YES                  | 30                               |
| 19          | 1.2                                                                   | 42                  | 50.4      | 12.2  | 6.80 | 32.0        | YES                  | 20                               |
| 20          | 1.2                                                                   | 42                  | 50.4      | 12.5  | 6.90 | 31.7        | YES                  | 20                               |
| 21          | 1.2                                                                   | 42                  | 50.4      | 12.0  | 6.80 | 32.4        | YES                  | 20                               |
| 22          | 1.2                                                                   | 42                  | 50.4      | 12.6  | 6.80 | 30.4        | YES                  | 20                               |
| 23          | 1.2                                                                   | 42                  | 50.4      | 12.7  | 6.90 | 31.3        | YES                  | 30                               |
| 24          | 1.2                                                                   | 42                  | 50.4      | 12.3  | 6.90 | 32.9        | YES                  | 30                               |
| 25          | 1.2                                                                   | 42                  | 50.4      | 11.9  | 6.90 | 33.7        | YES                  | 30                               |
| 26          | 1.2                                                                   | 42                  | 50.4      | 12.4  | 6.90 | 32.7        | YES                  | 20                               |
| 27          | 1.2                                                                   | 42                  | 50.4      | 12.1  | 6.80 | 32.2        | YES                  | 20                               |
| 28          | 1.2                                                                   | 42                  | 50.4      | 12.3  | 6.90 | 32.9        | YES                  | 20                               |
| 29          | 1.2                                                                   | 42                  | 50.4      | 12.1  | 6.90 | 33.3        | YES                  | 20                               |
| 30          | 1.2                                                                   | 42                  | 50.4      | 12.3  | 6.90 | 32.9        | YES                  | 30                               |
| 31          | 1                                                                     | 42                  | 42.0      | 12.3  | 6.80 | 31.1        | YES                  | 30                               |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013