

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Aug.2025

System Name: Whistler's Bend		ID#: 41 93944		WTP ID: TP-		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	115.00	115.00	0.00	35.00	0.42	0.42
2	115.00	115.00	0.00	35.00	0.49	0.49
3	20.00	20.00	0.00	35.00	0.65	0.65
4	120.00	150.00	-30.00	35.00	0.81	0.81
5	120.00	150.00	-30.00	35.00	0.73	0.73
6	120.00	140.00	-20.00	35.00	0.83	0.83
7	120.00	140.00	-20.00	30.00	0.91	0.91
8	20.00	20.00	0.00	30.00	0.41	0.41
9	20.00	20.00	0.00	30.00	0.74	0.74
10	120.00	150.00	-30.00	30.00	0.83	0.83
11	20.00	20.00	0.00	30.00	0.14	0.14
12	20.00	20.00	0.00	30.00	0.42	0.42
13	20.00	20.00	0.00	30.00	0.61	0.61
14	20.00	20.00	0.00	30.00	0.86	0.86
15	120.00	120.00	0.00	30.00	0.86	0.86
16	120.00	145.00	-25.00	30.00	0.93	0.93
17	120.00	140.00	-20.00	30.00	0.96	0.96
18	120.00	140.00	-20.00	30.00	0.41	0.41
19	120.00	140.00	-20.00	30.00	0.48	0.48
20	120.00	120.00	0.00	30.00	0.51	0.51
21	120.00	120.00	0.00	30.00	0.19	0.19
22	120.00	120.00	0.00	30.00	0.22	0.22
23	120.00	120.00	0.00	30.00	0.51	0.51
24	120.00	125.00	-5.00	30.00	0.86	0.86
25	120.00	125.00	-5.00	30.00	0.79	0.79
26	115.00	100.00	15.00	30.00	0.82	0.82
27	80.00	80.00	0.00	30.00	0.52	0.52
28	115.00	120.00	-5.00	30.00	0.55	0.55
29	115.00	125.00	-10.00	30.00	0.64	0.64
30	120.00	140.00	-20.00	30.00	0.73	0.73
31	80.00	80.00	0.00	30.00	0.95	0.95

Cartridge & Bag Filtration 95% of daily turbidity readings ≤ 1 NTU? ☒ Yes ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes ☐ No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes ☐ No All Cl2 residual at entry point ≥ 0.2 mg/l? ☒ Yes ☐ No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: Kelly Sharnoff SIGNATURE: <i>Kelly Sharnoff</i> PHONE #: (541) 671-9891 DATE: 9-9-25 CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Whistler's Bend	ID#: 41	93944	Month/Year:	Aug-25	Disinfection Giardia Log Inactiv:	1
--------------	-----------------	---------	-------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.5	42	63.0	23.5	7.50	19.6	YES	30
2	1.5	42	63.0	23.8	7.50	19.2	YES	30
3	1.5	42	63.0	20.1	7.50	24.7	YES	30
4	1.5	42	63.0	19.1	7.60	27.4	YES	20
5	1.5	42	63.0	21.5	7.60	23.3	YES	20
6	1.5	42	63.0	20.4	7.60	25.1	YES	20
7	1.5	42	63.0	20.7	7.60	24.6	YES	20
8	1.6	42	67.2	21.6	7.60	23.4	YES	30
9	1.6	42	67.2	20.3	7.60	25.6	YES	30
10	1.6	42	67.2	19.5	7.60	27.0	YES	30
11	1.6	42	67.2	21.9	7.60	23.0	YES	20
12	1.6	42	67.2	19.8	7.60	26.4	YES	20
13	1.6	42	67.2	22.1	7.80	24.4	YES	20
14	1.6	42	67.2	23.7	8.00	23.6	YES	20
15	1.6	42	67.2	21.1	7.60	24.2	YES	30
16	1.6	42	67.2	22.6	7.60	21.9	YES	30
17	1.6	42	67.2	21.2	7.60	24.1	YES	30
18	1.6	42	67.2	20.7	7.60	24.9	YES	20
19	1.6	42	67.2	20.4	7.60	25.4	YES	20
20	1.6	42	67.2	20.5	7.60	25.2	YES	20
21	1.6	42	67.2	20.6	7.60	25.1	YES	20
22	1.6	42	67.2	22.4	7.60	22.2	YES	30
23	1.6	42	67.2	24.2	7.60	19.7	YES	30
24	1.6	42	67.2	22.7	7.60	21.8	YES	30
25	1.1	42	46.2	21.6	7.70	23.0	YES	20
26	1	42	42.0	22.0	8.10	25.7	YES	20
27	1.2	42	50.4	20.7	7.90	26.6	YES	20
28	1.2	42	50.4	23.3	7.70	20.7	YES	30
29	1.4	42	58.8	24.1	7.60	19.3	YES	30
30	1.4	42	58.8	23.1	7.60	20.7	YES	30
31	1.4	42	58.8	24.6	7.70	19.4	YES	20

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350