

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Sep-25

System Name: Whistler's Bend		ID#: 41 93944		WTP ID: TP-		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	20.00	20.00	0.00	30.00	0.20	0.20
2	120.00	120.00	0.00	30.00	0.26	0.26
3	120.00	120.00	0.00	30.00	0.31	0.31
4	120.00	120.00	0.00	30.00	0.33	0.33
5	20.00	20.00	0.00	30.00	0.38	0.38
6	120.00	120.00	0.00	30.00	0.41	0.41
7	20.00	20.00	0.00	30.00	0.44	0.44
8	120.00	140.00	-20.00	30.00	0.61	0.61
9	120.00	140.00	-20.00	30.00	0.67	0.67
10	20.00	20.00	0.00	30.00	0.82	0.82
11	20.00	20.00	0.00	30.00	0.41	0.41
12	20.00	20.00	0.00	30.00	0.53	0.53
13	115.00	120.00	-5.00	30.00	0.16	0.16
14	20.00	20.00	0.00	30.00	0.21	0.21
15	20.00	20.00	0.00	30.00	0.34	0.34
16	120.00	130.00	-10.00	30.00	0.47	0.47
17	120.00	135.00	-15.00	30.00	0.52	0.52
18	20.00	20.00	0.00	30.00	0.57	0.57
19	20.00	20.00	0.00	30.00	0.64	0.64
20	20.00	20.00	0.00	30.00	0.80	0.80
21	20.00	20.00	0.00	30.00	0.82	0.82
22	120.00	140.00	-20.00	30.00	0.86	0.86
23	120.00	140.00	-20.00	30.00	0.88	0.88
24	120.00	120.00	0.00	30.00	0.88	0.88
25	20.00	20.00	0.00	30.00	0.88	0.88
26	120.00	145.00	-25.00	30.00	0.91	0.91
27	120.00	145.00	-25.00	30.00	0.92	0.92
28	120.00	145.00	-25.00	30.00	0.96	0.96
29	120.00	120.00	0.00	30.00	0.65	0.65
30	120.00	120.00	0.00	30.00	0.68	0.68
31						

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

Yes No

All daily turbidity readings $\leq$ 5 NTU?

Yes No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes No

All Cl2 residual at entry point $\geq$ 0.2 mg/l?

Yes No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Kelly Sherriff

SIGNATURE: Kelly Sherriff

DATE: 10-6-2025

PHONE #: (541) 671-9891

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:

Whistler's Bend

ID#: 41

93944

Month/Year:

Sep-25

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.4	42	58.8	24.1	7.70	20.1	YES	9
2	1.4	42	58.8	23.9	7.80	21.1	YES	9
3	1.4	42	58.8	23.2	7.80	22.2	YES	9
4	1.5	42	63.0	23.3	7.60	20.7	YES	9
5	1.5	42	63.0	23.7	7.90	22.5	YES	9
6	1.5	42	63.0	22.8	7.80	23.0	YES	9
7	1.5	42	63.0	22.9	7.80	22.9	YES	9
8	1.5	42	63.0	21.6	7.80	25.0	YES	9
9	1.6	42	67.2	20.8	7.60	24.7	YES	9
10	1.7	42	71.4	19.9	7.60	26.6	YES	9
11	1.8	42	75.6	19.2	7.70	29.2	YES	9
12	1.8	42	75.6	18.9	7.60	28.7	YES	9
13	1.8	42	75.6	18.9	7.60	28.7	YES	9
14	1.9	42	79.8	18.1	7.60	30.7	YES	9
15	1.9	42	79.8	18.4	7.60	30.0	YES	9
16	0.8	42	33.6	20.1	7.60	23.6	YES	9
17	1	42	42.0	17.8	7.60	28.2	YES	9
18	1	42	42.0	17.5	7.70	29.9	YES	9
19	1	42	42.0	17.6	7.60	28.6	YES	9
20	1.2	42	50.4	18.1	7.70	29.4	YES	9
21	1.3	42	54.6	18.4	7.60	28.1	YES	9
22	1.5	42	63.0	13.3	7.40	37.4	YES	9
23	1.5	42	63.0	13.8	7.60	39.0	YES	9
24	1.5	42	63.0	14.1	7.60	38.2	YES	9
25	1.5	42	63.0	14.5	7.70	38.6	YES	9
26	1.5	42	63.0	16.1	7.70	34.7	YES	9
27	1.5	42	63.0	14.2	7.80	40.9	YES	9
28	1.5	42	63.0	14.3	7.70	39.1	YES	9
29	1.5	42	63.0	14.7	7.90	41.0	YES	9
30	1.5	42	63.0	14.8	7.90	40.8	YES	9
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350