

OHA - Drinking Water Services - Surface Water Quality Data Form County: Jefferson

Cartridge or Bag Filtration 0.5 µ - Log Month/Year: September 2021

System Name: Camp Tamarack ID#: 41 94114 WTP ID: A

Day	PSI Before Filter 1	PSI After Filter 2	PSI Before Filter 3	PSI After Filter 4	PSID Filters 1 & 2	PSID Filters 3 & 4	PSID When to Change Filter	Daily Turbidity Reading [NTU]
1	63	58	58	58	5	0	30 15	0.163
2	68	62	62	60	6	2	15	0.146
3	70	60	60	60	20	0	15	0.105
4	80	53	53	52	27	1	15	0.104
5	80	72	72	71	8	+6	15	0.121
6	65	64	64	63	1	1	15	0.120
7	70	65	65	64	5	1	15	0.103
8	73	61	61	59	12	2	15	0.157
9	73	71	71	70	2	1	15	0.096
10	63	61	61	59	2	2	15	0.130
11	70	67	67	65	3	2	15	0.111
12	65	60	60	58	5	2	30 15	0.102
13	74	61	61	59	13	2	15	0.080
14	69	62	62	59	7	3	15	0.126
15	74	66	66	63	8	3	15	0.084
16	66	43	43	39	23	4	15	0.143
17	71	66	66	62	5	4	15	0.141
18	65	44	44	39	11	5	15	0.152
19	75	59	59	55	16	4	15	0.155
20	80	60	60	56	20	4	15	0.167
21	69	60	60	52	9	8	15	0.139
22	73	59	58	38	15	20	15	0.062
23	73	60	60	59	13	1	15	0.153
24	65	52	52	51	13	1	15	0.139
25	65	57	57	56	8	1	15	0.108
26	76	48	48	48	28	1	30 15	0.084
27	70	65	65	63	5	2	15	0.096
28	74	59	59	56	15	3	15	0.079
29	65	52	52	51	13	1	15	0.091
30	68	48	48	46	20	2	15	0.109
31							15	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU? Yes / No	Yes / No	Yes / No	
Notes: PSI = pounds per square inch		PRINTED NAME:	
PSID = pounds per square inch difference (before filter - after filter)		SIGNATURE:	
PSID When to Change Filter = Refer to manufacturer's specifications at what PSID to change the filter.		DATE:	
PHONE #: ()		CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values

